

Отчет о суточных параметрах ГВС  
(01.11.2024 0:00:00 - 30.11.2024 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: Карат-30X Заводской номер: 11432221

Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.11.2024	53.03	1.287	1.270	4.15	0.061	24.0		Ok
02.11.2024	53.91	1.776	1.752	4.21	0.086	24.0		Ok
03.11.2024	53.36	1.621	1.599	4.07	0.077	24.0		Ok
04.11.2024	52.89	1.807	1.783	3.88	0.085	24.0		Ok
05.11.2024	53.20	1.301	1.284	4.02	0.062	24.0		Ok
06.11.2024	52.55	1.308	1.291	4.10	0.061	24.0		Ok
07.11.2024	53.33	1.877	1.852	4.17	0.089	24.0		Ok
08.11.2024	53.57	1.668	1.646	4.24	0.080	24.0		Ok
09.11.2024	54.84	1.651	1.628	3.78	0.081	24.0		Ok
10.11.2024	53.29	1.515	1.495	3.13	0.072	24.0		Ok
11.11.2024	53.79	1.750	1.726	3.14	0.084	24.0		Ok
12.11.2024	52.99	1.586	1.565	4.15	0.075	24.0		Ok
13.11.2024	53.53	1.334	1.316	4.24	0.064	24.0		Ok
14.11.2024	52.60	1.180	1.165	4.17	0.055	24.0		Ok
15.11.2024	54.02	2.355	2.323	4.07	0.114	24.0		Ok
16.11.2024	53.60	1.658	1.636	4.10	0.079	24.0		Ok
17.11.2024	54.06	1.580	1.558	3.72	0.076	24.0		Ok
18.11.2024	53.80	1.489	1.469	4.16	0.072	24.0		Ok
19.11.2024	52.28	1.301	1.284	4.26	0.061	24.0		Ok
20.11.2024	52.83	1.614	1.593	4.21	0.076	24.0		Ok
21.11.2024	52.93	1.494	1.475	4.20	0.071	24.0		Ok
22.11.2024	53.08	1.716	1.694	4.20	0.081	24.0		Ok
23.11.2024	54.31	2.035	2.007	4.20	0.099	24.0		Ok
24.11.2024	53.12	1.822	1.798	4.01	0.086	24.0		Ok
25.11.2024	53.48	1.872	1.847	4.17	0.090	24.0		Ok
26.11.2024	53.33	1.624	1.602	4.31	0.077	24.0		Ok
27.11.2024	52.32	1.328	1.311	4.33	0.062	24.0		Ok
28.11.2024	53.32	1.384	1.366	4.23	0.066	24.0		Ok
29.11.2024	53.96	1.758	1.734	4.26	0.085	24.0		Ok
30.11.2024	54.18	1.429	1.409	4.19	0.069	24.0		Ok
Средние:	53.38	---	---	4.07	---	---		
Итого:	---	48.120	47.480	---	2.299	720.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
31.10.2024	1657.071	1634.467	79.846	26178.7
30.11.2024	1705.191	1681.946	82.145	26898.7
Итого:	48.120	47.479	2.299	720.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.11.2024 0:00:00 - 30.11.2024 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

ПРЭМ SN 334995

Обратка: ПРЭМ SN 333703

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.11.2024	66.75	46.49	20.26	21.08	20.53	2.64	20.62	20.29	1.61	0.33	9.00	5.00	0.418	24.0	0.0	
02.11.2024	66.84	46.44	20.40	21.35	20.80	2.61	20.88	20.56	1.54	0.32	9.00	5.00	0.427	24.0	0.0	
03.11.2024	70.79	47.79	23.00	21.52	21.00	2.45	21.04	20.76	1.34	0.28	9.00	5.00	0.485	24.0	0.0	
04.11.2024	72.47	48.68	23.79	22.08	21.56	2.38	21.60	21.32	1.30	0.28	9.00	5.00	0.516	24.0	0.0	
05.11.2024	74.93	48.35	26.58	19.82	19.38	2.24	19.34	19.14	1.04	0.20	9.00	5.00	0.516	24.0	0.0	
06.11.2024	83.33	51.02	32.31	18.72	18.39	1.78	18.21	18.15	0.33	0.06	9.00	5.00	0.588	24.0	0.0	
07.11.2024	80.84	53.16	27.68	22.56	22.13	1.92	21.85	21.89	-0.18	-0.04	9.00	5.00	0.605	24.0	0.0	
08.11.2024	77.15	52.07	25.08	22.47	22.00	2.11	21.87	21.76	0.50	0.11	9.00	5.00	0.551	24.0	0.0	
09.11.2024	68.51	46.29	22.22	20.35	19.85	2.49	19.87	19.61	1.32	0.26	9.00	5.00	0.442	24.0	0.0	
10.11.2024	70.04	47.05	22.99	20.67	20.16	2.50	20.20	19.92	1.40	0.28	9.00	5.00	0.465	24.0	0.0	
11.11.2024	75.07	49.82	25.25	21.29	20.84	2.14	20.83	20.60	1.11	0.23	9.00	5.00	0.529	24.0	0.0	
12.11.2024	75.58	50.53	25.05	21.93	21.46	2.17	21.44	21.22	1.03	0.22	9.00	5.00	0.539	24.0	0.0	
13.11.2024	74.38	51.15	23.23	23.25	22.74	2.22	22.72	22.50	0.97	0.22	9.00	5.00	0.529	24.0	0.0	
14.11.2024	69.99	47.55	22.44	20.94	20.44	2.42	20.46	20.20	1.28	0.26	9.00	5.00	0.458	24.0	0.0	
15.11.2024	71.75	49.19	22.56	22.33	21.82	2.31	21.85	21.58	1.24	0.27	9.00	5.00	0.496	24.0	0.0	
16.11.2024	70.51	48.50	22.01	21.65	21.14	2.38	21.17	20.90	1.28	0.27	9.00	5.00	0.470	24.0	0.0	
17.11.2024	70.02	48.17	21.85	21.69	21.18	2.38	21.21	20.94	1.28	0.27	9.00	5.00	0.466	24.0	0.0	
18.11.2024	69.12	47.95	21.17	21.65	21.14	2.38	21.17	20.90	1.28	0.27	9.00	5.00	0.451	24.0	0.0	
19.11.2024	68.83	47.70	21.13	21.98	21.45	2.44	21.50	21.21	1.36	0.29	9.00	5.00	0.457	24.0	0.0	
20.11.2024	69.53	47.83	21.70	21.75	21.25	2.33	21.27	21.01	1.23	0.26	9.00	5.00	0.463	24.0	0.0	
21.11.2024	69.81	47.88	21.93	21.61	21.11	2.34	21.13	20.87	1.24	0.26	9.00	5.00	0.465	24.0	0.0	
22.11.2024	69.72	48.69	21.03	22.92	22.39	2.34	22.44	22.15	1.30	0.29	9.00	5.00	0.474	24.0	0.0	
23.11.2024	69.02	47.79	21.23	22.01	21.50	2.34	21.53	21.26	1.26	0.27	9.00	5.00	0.459	24.0	0.0	
24.11.2024	69.05	47.93	21.12	21.96	21.44	2.40	21.48	21.20	1.31	0.28	9.00	5.00	0.457	24.0	0.0	
25.11.2024	72.25	49.86	22.39	22.87	22.37	2.21	22.37	22.13	1.08	0.24	9.00	5.00	0.502	24.0	0.0	
26.11.2024	77.75	53.15	24.60	24.20	23.74	1.92	23.56	23.50	0.25	0.06	9.00	5.00	0.582	24.0	0.0	
27.11.2024	80.50	54.54	25.96	24.05	23.62	1.80	23.33	23.36	-0.13	-0.03	9.00	5.00	0.608	24.0	0.0	
28.11.2024	85.44	57.44	28.00	24.53	24.14	1.60	23.81	23.73	0.34	0.08	9.00	5.00	0.668	24.0	0.0	
29.11.2024	83.79	56.09	27.70	23.61	23.22	1.67	22.89	22.97	-0.35	-0.08	9.00	5.00	0.637	24.0	0.0	
30.11.2024	77.05	53.32	23.73	23.96	23.50	1.94	23.37	23.19	0.77	0.18	9.00	5.00	0.557	24.0	0.0	
Средние:	73.36	49.75	23.61	---	---	2.23	---	---	0.98	---	9.00	5.00	---	---	---	
Итого:	---	---	---	660.80	646.29	---	645.01	638.82	---	6.19	---	---	15.280	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.10.2024	5086.52	5185.08	4951.80	5131.43	-179.63	161.068	16139.0	1.0
30.11.2024	5747.32	5831.37	5596.81	5770.25	-173.44	176.348	16859.0	1.0
Итого:	660.80	646.29	645.01	638.82	6.19	15.280	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации