

Отчет о суточных параметрах
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Волгодонская ул, д. 18 (ООО "УК "ЖКХ Кировский")

Прибор: ТМК-Н13 Заводской номер: 1182

Точка измерения: ТС1; Ресурс: ТС

Схема измерений: Закрытая система, ПР в подающем ТП и обратном ТП (измерение Q по G1)

Дата	t1	t2	M1	M2	P1	P2	Qo	txв	BHP	NS
	°C	°C	т	т	кгс/см2	кгс/см2	Гкал	°C	ч	
01.03.2025	55.30	42.30	159.09	159.20	5.00	5.00	2.071	5.00	24.0	
02.03.2025	53.20	41.00	159.24	159.30	5.00	5.00	1.948	5.00	24.0	
03.03.2025	55.40	42.30	159.03	159.16	5.00	5.00	2.075	5.00	24.0	
04.03.2025	56.80	43.30	159.88	160.09	5.00	5.00	2.168	5.00	24.0	*
05.03.2025	56.90	43.10	160.95	161.19	5.00	5.00	2.206	5.00	24.0	
06.03.2025	56.00	42.80	161.04	161.21	5.00	5.00	2.120	5.00	24.0	
07.03.2025	56.80	43.30	161.00	161.24	5.00	5.00	2.168	5.00	24.0	
08.03.2025	57.70	43.80	160.95	161.21	5.00	5.00	2.236	5.00	24.0	
09.03.2025	57.50	43.60	160.98	161.24	5.00	5.00	2.236	5.00	24.0	
10.03.2025	55.10	42.40	161.15	161.29	5.00	5.00	2.040	5.00	24.0	
11.03.2025	53.20	41.30	161.31	161.34	5.00	5.00	1.923	5.00	24.0	
12.03.2025	49.20	38.90	161.59	161.54	5.00	5.00	1.655	5.00	24.0	
13.03.2025	49.10	38.90	161.58	161.52	5.00	5.00	1.640	5.00	24.0	
14.03.2025	48.70	38.80	161.57	161.54	5.00	5.00	1.603	5.00	24.0	
15.03.2025	33.50	28.60	137.34	164.70	5.00	5.00	0.675	5.00	24.0	*
16.03.2025	49.00	38.70	164.42	164.32	5.00	5.00	1.695	5.00	24.0	
17.03.2025	49.20	39.70	170.61	170.62	5.00	5.00	1.620	5.00	24.0	
18.03.2025	51.50	40.90	170.50	170.61	5.00	5.00	1.809	5.00	24.0	
19.03.2025	54.90	43.00	170.44	170.52	5.00	5.00	2.034	5.00	24.0	
20.03.2025	53.50	42.00	170.85	170.94	5.00	5.00	1.960	5.00	24.0	
21.03.2025	52.00	40.90	170.95	171.02	5.00	5.00	1.888	5.00	24.0	
22.03.2025	52.10	41.10	170.94	171.03	5.00	5.00	1.879	5.00	24.0	
23.03.2025	50.10	39.90	171.03	171.05	5.00	5.00	1.747	5.00	24.0	
24.03.2025	49.30	39.50	171.12	171.06	5.00	5.00	1.678	5.00	24.0	
25.03.2025	49.50	39.70	171.15	171.08	5.00	5.00	1.665	5.00	24.0	
26.03.2025	48.50	39.20	171.17	171.13	5.00	5.00	1.582	5.00	24.0	
27.03.2025	48.00	38.90	171.17	171.15	5.00	5.00	1.549	5.00	24.0	
28.03.2025	48.10	39.10	171.19	171.14	5.00	5.00	1.537	5.00	24.0	
29.03.2025	47.60	38.70	171.17	171.17	5.00	5.00	1.518	5.00	24.0	
30.03.2025	48.30	39.20	171.18	171.07	5.00	5.00	1.561	5.00	24.0	
31.03.2025	49.50	40.00	171.06	171.04	5.00	5.00	1.614	5.00	24.0	
Средние:	51.47	40.48	---	---	5.00	5.00	---	5.00	---	
Итого:	---	---	5115.68	5144.71	---	---	56.103	---	743.9	

Дата	M1	M2	Qo	BHP
	т	т	Гкал	ч
28.02.2025	369830.47	520825.22	3839.294	67107.8
31.03.2025	374946.15	525969.93	3895.397	67851.7
Итого:	5115.68	5144.71	56.103	743.9

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Волгодонская ул, д. 18 (ООО "УК "ЖКХ Кировский")

Прибор: ТМК-Н13 Заводской номер: 1182

Точка измерения: ТС2; Ресурс: ГВС

Схема измерений: ГВС

Дата	t3	M3	P3	Qo	txв	BHP	NS
	°C	т	кгс/см2	Гкал	°C	ч	
01.03.2025	62.20	11.39	5.00	0.659	5.00	24.0	*
02.03.2025	61.40	8.34	5.00	0.484	5.00	24.0	*
03.03.2025	61.00	6.72	5.00	0.388	5.00	24.0	*
04.03.2025	60.40	7.28	5.00	0.420	5.00	24.0	*
05.03.2025	61.00	7.30	5.00	0.423	5.00	24.0	*
06.03.2025	61.10	6.98	5.00	0.402	5.00	23.0	*
07.03.2025	61.90	8.29	5.00	0.478	5.00	24.0	*
08.03.2025	60.20	7.77	5.00	0.450	5.00	24.0	*
09.03.2025	61.20	7.75	5.00	0.446	5.00	24.0	*
10.03.2025	61.00	7.30	5.00	0.421	5.00	24.0	*
11.03.2025	60.30	8.18	5.00	0.461	5.00	24.0	*
12.03.2025	58.40	7.03	5.00	0.383	5.00	24.0	*
13.03.2025	58.80	7.07	5.00	0.387	5.00	24.0	*
14.03.2025	61.00	7.70	5.00	0.437	5.00	24.0	*
15.03.2025	33.10	2.59	5.00	0.107	5.00	24.0	*
16.03.2025	58.40	10.17	5.00	0.565	5.00	24.0	*
17.03.2025	58.10	8.03	5.00	0.436	5.00	24.0	*
18.03.2025	61.10	8.36	5.00	0.481	5.00	24.0	*
19.03.2025	61.80	7.19	5.00	0.413	5.00	24.0	*
20.03.2025	60.80	7.57	5.00	0.432	5.00	24.0	*
21.03.2025	61.60	7.86	5.00	0.452	5.00	24.0	*
22.03.2025	61.50	8.91	5.00	0.516	5.00	24.0	*
23.03.2025	58.40	8.75	5.00	0.474	5.00	24.0	*
24.03.2025	58.20	7.15	5.00	0.390	5.00	24.0	*
25.03.2025	59.40	6.71	5.00	0.383	5.00	24.0	*
26.03.2025	59.80	7.39	5.00	0.419	5.00	24.0	*
27.03.2025	59.50	7.04	5.00	0.396	5.00	24.0	*
28.03.2025	59.10	6.93	5.00	0.389	5.00	24.0	*
29.03.2025	59.00	7.70	5.00	0.427	5.00	24.0	*
30.03.2025	57.90	7.66	5.00	0.420	5.00	24.0	*
31.03.2025	64.40	6.73	5.00	0.385	5.00	22.9	*
Средние:	59.42	---	5.00	---	5.00	---	
Итого:	---	235.85	---	13.324	---	741.9	

Дата	M3	Qo	BHP
	т	Гкал	ч
28.02.2025	20782.14	1031.590	68954.4
31.03.2025	21017.99	1044.914	69696.2
Итого:	235.85	13.324	741.9

Представитель абонента

Представитель энергоснабжающей организации