

Отчет о суточных параметрах ГВС  
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")  
Прибор: Карат-30X Заводской номер: 11432221  
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.03.2025	52.94	1.415	1.396	4.24	0.067	24.0		Ok
02.03.2025	52.86	1.583	1.562	3.96	0.075	24.0		Ok
03.03.2025	52.95	1.579	1.558	4.22	0.075	24.0		Ok
04.03.2025	52.00	1.315	1.298	4.26	0.061	24.0		Ok
05.03.2025	52.25	1.360	1.343	4.21	0.063	24.0		Ok
06.03.2025	52.93	1.253	1.237	4.19	0.059	24.0		Ok
07.03.2025	52.65	1.634	1.613	4.34	0.077	24.0		Ok
08.03.2025	52.35	1.642	1.621	4.22	0.077	24.0		Ok
09.03.2025	54.25	1.992	1.965	4.03	0.097	24.0		Ok
10.03.2025	54.01	2.093	2.065	4.19	0.101	24.0		Ok
11.03.2025	53.40	1.603	1.582	4.29	0.077	24.0		Ok
12.03.2025	52.86	1.647	1.626	4.31	0.078	24.0		Ok
13.03.2025	52.41	1.932	1.907	4.28	0.090	24.0		Ok
14.03.2025	53.06	1.864	1.840	4.25	0.088	24.0		Ok
15.03.2025	45.30	1.577	1.562	4.32	0.063	24.0		Ok
16.03.2025	38.25	2.015	2.001	4.15	0.067	24.0		Ok
17.03.2025	52.87	1.466	1.447	3.84	0.069	24.0		Ok
18.03.2025	53.70	1.533	1.512	4.02	0.074	24.0		Ok
19.03.2025	53.62	1.561	1.540	4.00	0.075	24.0		Ok
20.03.2025	53.29	1.680	1.658	4.02	0.080	24.0		Ok
21.03.2025	53.23	1.506	1.486	4.05	0.072	24.0		Ok
22.03.2025	54.60	1.849	1.823	3.96	0.090	24.0		Ok
23.03.2025	53.63	2.034	2.007	3.67	0.098	24.0		Ok
24.03.2025	53.55	1.657	1.635	4.06	0.079	24.0		Ok
25.03.2025	53.54	1.523	1.503	4.08	0.073	24.0		Ok
26.03.2025	53.77	1.751	1.727	4.04	0.084	24.0		Ok
27.03.2025	53.66	1.888	1.863	3.94	0.091	24.0		Ok
28.03.2025	53.84	1.764	1.740	4.04	0.085	24.0		Ok
29.03.2025	52.54	1.909	1.884	3.94	0.090	24.0		Ok
30.03.2025	54.14	2.024	1.996	3.73	0.098	24.0		Ok
31.03.2025	54.17	1.968	1.941	3.90	0.095	24.0		Ok
Средние:	52.54	---	---	4.09	---	---		
Итого:	---	52.617	51.938	---	2.466	744.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
28.02.2025	1841.732	1816.656	88.698	29057.3
31.03.2025	1894.349	1868.594	91.164	29801.3
Итого:	52.617	51.938	2.466	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.03.2025 0:00:00 - 31.03.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Подача: Счетчик воды: ПРЭМ SN 334995  
Обратка: ПРЭМ SN 333703

Датчик температуры: КТСП-Н SN 32048г  
КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2025	77.63	44.14	33.49	13.77	13.58	1.39	13.38	13.40	-0.15	-0.02	9.00	5.00	0.448	24.0	0.0	
02.03.2025	74.84	42.67	32.17	13.54	13.33	1.56	13.29	13.29	0.00	0.00	9.00	5.00	0.428	24.0	0.0	
03.03.2025	77.21	44.56	32.65	14.32	14.12	1.41	13.89	13.88	0.07	0.01	9.00	5.00	0.452	24.0	0.0	
04.03.2025	79.10	45.29	33.81	14.25	14.06	1.34	13.82	13.86	-0.29	-0.04	9.00	5.00	0.469	24.0	0.0	
05.03.2025	79.79	44.64	35.15	13.63	13.47	1.18	13.20	13.30	-0.75	-0.10	9.00	5.00	0.464	24.0	0.0	
06.03.2025	78.38	44.78	33.60	13.89	13.70	1.38	13.46	13.49	-0.22	-0.03	9.00	5.00	0.454	24.0	0.0	
07.03.2025	78.60	45.19	33.41	14.19	14.01	1.28	13.74	13.77	-0.22	-0.03	9.00	5.00	0.458	24.0	0.0	
08.03.2025	80.14	45.75	34.39	14.23	14.06	1.20	13.78	13.85	-0.51	-0.07	9.00	5.00	0.475	24.0	0.0	
09.03.2025	80.82	45.28	35.54	13.68	13.52	1.18	13.24	13.31	-0.53	-0.07	9.00	5.00	0.472	24.0	0.0	
10.03.2025	75.74	44.17	31.57	14.04	13.84	1.43	13.71	13.65	0.44	0.06	9.00	5.00	0.436	24.0	0.0	
11.03.2025	73.71	42.92	30.79	13.57	13.36	1.56	13.29	13.22	0.53	0.07	9.00	5.00	0.412	24.0	0.0	
12.03.2025	67.75	39.98	27.77	12.86	12.60	2.04	12.62	12.60	0.16	0.02	9.00	5.00	0.351	24.0	0.0	
13.03.2025	66.58	39.79	26.79	12.81	12.54	2.13	12.57	12.54	0.24	0.03	9.00	5.00	0.336	24.0	0.0	
14.03.2025	67.36	40.36	27.00	13.54	13.27	2.01	13.30	13.27	0.23	0.03	9.00	5.00	0.361	24.0	0.0	
15.03.2025	67.94	42.25	25.69	14.69	14.42	1.86	14.45	14.25	1.39	0.20	9.00	5.00	0.372	24.0	0.0	
16.03.2025	68.01	41.00	27.01	13.23	12.97	1.98	12.99	12.96	0.23	0.03	9.00	5.00	0.353	24.0	0.0	
17.03.2025	67.23	40.44	26.79	12.90	12.64	2.04	12.66	12.64	0.16	0.02	9.00	5.00	0.339	24.0	0.0	
18.03.2025	71.33	41.86	29.47	13.19	12.96	1.76	12.94	12.85	0.70	0.09	9.00	5.00	0.383	24.0	0.0	
19.03.2025	75.53	44.24	31.29	13.91	13.71	1.45	13.59	13.57	0.15	0.02	9.00	5.00	0.427	24.0	0.0	
20.03.2025	73.53	43.55	29.98	13.65	13.43	1.62	13.39	13.32	0.52	0.07	9.00	5.00	0.403	24.0	0.0	
21.03.2025	72.54	42.36	30.18	13.16	12.94	1.69	12.92	12.94	-0.15	-0.02	9.00	5.00	0.390	24.0	0.0	
22.03.2025	72.20	42.70	29.50	13.51	13.29	1.64	13.27	13.24	0.23	0.03	9.00	5.00	0.393	24.0	0.0	
23.03.2025	69.87	41.09	28.78	12.79	12.55	1.89	12.55	12.55	0.00	0.00	9.00	5.00	0.362	24.0	0.0	
24.03.2025	67.31	40.86	26.45	13.31	13.06	1.90	13.07	13.06	0.08	0.01	9.00	5.00	0.346	24.0	0.0	
25.03.2025	67.85	41.51	26.34	13.70	13.44	1.92	13.46	13.38	0.60	0.08	9.00	5.00	0.354	24.0	0.0	
26.03.2025	67.58	41.70	25.88	13.85	13.60	1.82	13.61	13.53	0.59	0.08	9.00	5.00	0.354	24.0	0.0	
27.03.2025	66.16	41.02	25.14	13.74	13.49	1.84	13.50	13.47	0.22	0.03	9.00	5.00	0.341	24.0	0.0	
28.03.2025	66.17	41.25	24.92	13.97	13.71	1.88	13.73	13.64	0.66	0.09	9.00	5.00	0.343	24.0	0.0	
29.03.2025	65.94	40.29	25.65	13.27	13.02	1.90	13.03	13.02	0.08	0.01	9.00	5.00	0.334	24.0	0.0	
30.03.2025	66.09	40.57	25.52	13.40	13.16	1.81	13.16	13.13	0.23	0.03	9.00	5.00	0.335	24.0	0.0	
31.03.2025	66.65	42.26	24.39	14.89	14.64	1.69	14.65	14.50	1.03	0.15	9.00	5.00	0.358	24.0	0.0	
Средние:	71.92	42.53	29.39	---	---	1.67	---	---	0.18	---	9.00	5.00	---	---	---	
Итого:	---	---	---	423.48	416.49	---	414.26	413.48	---	0.78	---	---	12.203	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
28.02.2025	7925.20	7976.22	7710.42	7883.39	-172.97	233.094	19019.0	1.0
31.03.2025	8348.68	8392.71	8124.68	8296.87	-172.19	245.297	19763.0	1.0
Итого:	423.48	416.49	414.26	413.48	0.78	12.203	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации