

Отчет о суточных параметрах ГВС  
(01.04.2025 0:00:00 - 30.04.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")  
Прибор: Карат-30X Заводской номер: 11432221  
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.04.2025	53.67	1.890	1.865	3.97	0.091	24.0		Ok
02.04.2025	54.11	2.054	2.026	4.02	0.099	24.0		Ok
03.04.2025	54.17	2.031	2.003	4.00	0.098	24.0		Ok
04.04.2025	53.37	1.857	1.832	4.06	0.089	24.0		Ok
05.04.2025	53.95	2.020	1.993	3.96	0.097	24.0		Ok
06.04.2025	53.34	1.936	1.910	3.70	0.092	24.0		Ok
07.04.2025	52.94	1.391	1.373	3.91	0.066	24.0		Ok
08.04.2025	52.84	1.290	1.273	3.99	0.061	24.0		Ok
09.04.2025	53.81	1.817	1.792	4.03	0.087	24.0		Ok
10.04.2025	48.53	1.322	1.307	2.81	0.057	24.0		Ok
11.04.2025	53.90	1.703	1.680	4.33	0.082	24.0		Ok
12.04.2025	54.03	2.123	2.094	4.24	0.103	24.0		Ok
13.04.2025	52.67	1.674	1.652	4.02	0.079	24.0		Ok
14.04.2025	52.47	1.583	1.563	4.19	0.074	24.0		Ok
15.04.2025	52.28	1.523	1.504	4.21	0.071	24.0		Ok
16.04.2025	53.72	2.066	2.038	4.17	0.099	24.0		Ok
17.04.2025	53.92	1.836	1.811	4.17	0.089	24.0		Ok
18.04.2025	53.13	2.105	2.077	4.29	0.100	24.0		Ok
19.04.2025	54.57	2.192	2.162	4.27	0.107	24.0		Ok
20.04.2025	52.77	1.590	1.569	4.20	0.075	24.0		Ok
21.04.2025	53.34	1.746	1.723	4.34	0.083	24.0		Ok
22.04.2025	53.35	1.558	1.537	4.32	0.074	24.0		Ok
23.04.2025	53.83	1.977	1.950	4.26	0.095	24.0		Ok
24.04.2025	54.04	1.759	1.735	4.27	0.085	24.0		Ok
25.04.2025	53.76	1.906	1.880	4.38	0.092	24.0		Ok
26.04.2025	51.60	1.845	1.822	4.24	0.085	24.0		Ok
27.04.2025	53.25	2.007	1.980	4.09	0.096	24.0		Ok
28.04.2025	53.01	1.657	1.635	4.29	0.078	24.0		Ok
29.04.2025	53.19	1.902	1.877	4.35	0.090	24.0		Ok
30.04.2025	53.23	1.513	1.493	4.32	0.072	24.0		Ok
Средние:	53.23	---	---	4.11	---	---		
Итого:	---	53.873	53.159	---	2.567	720.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
31.03.2025	1894.349	1868.594	91.164	29801.3
30.04.2025	1948.222	1921.752	93.731	30521.3
Итого:	53.873	53.158	2.567	720.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.04.2025 0:00:00 - 30.04.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

ПРЭМ SN 334995

Обратка: ПРЭМ SN 333703

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.04.2025	66.44	42.60	23.84	15.22	14.94	1.86	14.98	14.77	1.41	0.21	9.00	5.00	0.360	24.0	0.0	
02.04.2025	66.01	42.02	23.99	14.71	14.42	1.99	14.47	14.27	1.39	0.20	9.00	5.00	0.347	24.0	0.0	
03.04.2025	65.63	40.82	24.81	13.56	13.28	2.09	13.32	13.25	0.53	0.07	9.00	5.00	0.333	24.0	0.0	
04.04.2025	65.61	40.27	25.34	13.37	13.08	2.19	13.13	13.08	0.38	0.05	9.00	5.00	0.332	24.0	0.0	
05.04.2025	67.94	42.66	25.28	14.87	14.60	1.83	14.62	14.45	1.17	0.17	9.00	5.00	0.369	24.0	0.0	
06.04.2025	65.78	40.68	25.10	13.32	13.03	2.20	13.08	13.01	0.54	0.07	9.00	5.00	0.329	24.0	0.0	
07.04.2025	66.10	40.08	26.02	13.19	12.92	2.07	12.95	12.92	0.23	0.03	9.00	5.00	0.339	24.0	0.0	
08.04.2025	66.12	40.86	25.26	13.65	13.37	2.07	13.41	13.36	0.37	0.05	9.00	5.00	0.339	24.0	0.0	
09.04.2025	65.82	40.72	25.10	13.49	13.22	2.02	13.25	13.22	0.23	0.03	9.00	5.00	0.334	24.0	0.0	
10.04.2025	65.13	38.54	26.59	11.65	11.39	2.26	11.41	11.39	0.18	0.02	9.00	5.00	0.302	24.0	0.0	
11.04.2025	64.80	37.96	26.84	11.54	11.27	2.37	11.30	11.27	0.27	0.03	9.00	5.00	0.305	24.0	0.0	
12.04.2025	65.15	38.40	26.75	12.05	11.79	2.18	11.81	11.79	0.17	0.02	9.00	5.00	0.313	24.0	0.0	
13.04.2025	65.38	38.06	27.32	12.00	11.73	2.28	11.76	11.73	0.26	0.03	9.00	5.00	0.322	24.0	0.0	
14.04.2025	65.89	39.52	26.37	13.35	13.07	2.12	13.11	13.07	0.31	0.04	9.00	5.00	0.348	24.0	0.0	
15.04.2025	66.05	40.70	25.35	13.86	13.59	1.97	13.62	13.55	0.52	0.07	9.00	5.00	0.350	24.0	0.0	
16.04.2025	65.86	40.72	25.14	13.60	13.31	2.16	13.36	13.26	0.75	0.10	9.00	5.00	0.336	24.0	0.0	
17.04.2025	65.41	39.08	26.33	12.49	12.22	2.19	12.25	12.22	0.25	0.03	9.00	5.00	0.323	24.0	0.0	
18.04.2025	66.09	40.90	25.19	14.01	13.72	2.09	13.77	13.68	0.66	0.09	9.00	5.00	0.349	24.0	0.0	
19.04.2025	67.10	42.85	24.25	14.96	14.67	1.96	14.71	14.50	1.44	0.21	9.00	5.00	0.359	24.0	0.0	
20.04.2025	66.28	42.49	23.79	13.78	13.50	2.05	13.53	13.41	0.89	0.12	9.00	5.00	0.322	24.0	0.0	
21.04.2025	65.40	39.87	25.53	12.38	12.12	2.12	12.14	12.12	0.16	0.02	9.00	5.00	0.309	24.0	0.0	
22.04.2025	66.37	42.72	23.65	14.24	13.97	1.91	14.00	13.82	1.29	0.18	9.00	5.00	0.333	24.0	0.0	
23.04.2025	66.13	41.33	24.80	13.94	13.68	1.88	13.70	13.62	0.59	0.08	9.00	5.00	0.340	24.0	0.0	
24.04.2025	66.32	42.48	23.84	14.16	13.88	2.00	13.92	13.72	1.45	0.20	9.00	5.00	0.332	24.0	0.0	
25.04.2025	65.44	41.07	24.37	12.80	12.54	2.05	12.56	12.49	0.56	0.07	9.00	5.00	0.310	24.0	0.0	
26.04.2025	65.78	41.13	24.65	12.82	12.56	2.05	12.58	12.56	0.16	0.02	9.00	5.00	0.311	24.0	0.0	
27.04.2025	65.48	40.17	25.31	12.53	12.27	2.10	12.29	12.27	0.16	0.02	9.00	5.00	0.312	24.0	0.0	
28.04.2025	65.59	38.61	26.98	11.92	11.68	2.03	11.68	11.68	0.00	0.00	9.00	5.00	0.318	24.0	0.0	
29.04.2025	67.13	40.81	26.32	13.59	13.31	2.08	13.35	13.29	0.45	0.06	9.00	5.00	0.355	24.0	0.0	
30.04.2025	65.82	41.20	24.62	13.90	13.63	1.96	13.66	13.55	0.81	0.11	9.00	5.00	0.338	24.0	0.0	
Средние:	65.94	40.64	25.29	---	---	2.07	---	---	0.58	---	9.00	5.00	---	---	---	
Итого:	---	---	---	400.95	392.76	---	393.72	391.32	---	2.40	---	---	9.969	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.03.2025	8348.68	8392.71	8124.68	8296.87	-172.19	245.297	19763.0	1.0
30.04.2025	8749.63	8785.47	8518.40	8688.19	-169.79	255.266	20483.0	1.0
Итого:	400.95	392.76	393.72	391.32	2.40	9.969	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации