

Отчет о суточных параметрах ГВС
(01.09.2025 0:00:00 - 30.09.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: Карат-30X Заводской номер: 11432221

Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.09.2025	49.31	2.269	2.243	3.82	0.099	24.0		Ok
02.09.2025	52.29	1.775	1.752	3.80	0.083	24.0		Ok
03.09.2025	52.45	1.881	1.857	3.65	0.088	24.0		Ok
04.09.2025	51.78	1.605	1.585	3.74	0.074	24.0		Ok
05.09.2025	51.45	1.829	1.806	3.82	0.084	24.0		Ok
06.09.2025	53.56	2.028	2.001	3.89	0.097	24.0		Ok
07.09.2025	53.63	2.477	2.444	3.41	0.119	24.0		Ok
08.09.2025	51.53	1.589	1.569	3.57	0.073	24.0		Ok
09.09.2025	51.25	1.762	1.740	3.54	0.080	24.0		Ok
10.09.2025	52.88	2.126	2.098	3.53	0.100	24.0		Ok
11.09.2025	52.80	2.061	2.034	3.68	0.097	24.0		Ok
12.09.2025	51.79	2.070	2.044	3.78	0.096	24.0		Ok
13.09.2025	51.78	1.911	1.887	3.87	0.088	24.0		Ok
14.09.2025	52.18	2.279	2.250	3.51	0.106	24.0		Ok
15.09.2025	50.95	1.750	1.729	3.65	0.079	24.0		Ok
16.09.2025	51.06	1.466	1.448	3.92	0.067	24.0		Ok
17.09.2025	51.59	1.916	1.892	3.80	0.088	24.0		Ok
18.09.2025	53.53	2.277	2.247	3.87	0.109	24.0		Ok
19.09.2025	52.90	2.224	2.195	3.89	0.105	24.0		Ok
20.09.2025	52.75	2.483	2.451	3.96	0.117	24.0		Ok
21.09.2025	52.80	2.274	2.244	3.58	0.107	24.0		Ok
22.09.2025	53.23	2.245	2.215	3.67	0.107	24.0		Ok
23.09.2025	53.32	2.379	2.347	3.83	0.113	24.0		Ok
24.09.2025	51.97	1.822	1.799	3.64	0.084	24.0		Ok
25.09.2025	53.11	2.106	2.078	3.80	0.100	24.0		Ok
26.09.2025	52.70	2.717	2.682	3.76	0.128	24.0		Ok
27.09.2025	54.30	2.468	2.434	3.87	0.120	24.0		Ok
28.09.2025	52.98	2.165	2.137	3.39	0.102	24.0		Ok
29.09.2025	53.59	2.606	2.571	3.50	0.125	24.0		Ok
30.09.2025	53.33	1.890	1.865	3.89	0.090	24.0		Ok
Средние:	52.43	---	---	3.72	---	---		
Итого:	---	62.450	61.645	---	2.927	720.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
31.08.2025	2088.512	2060.352	100.056	33056.7
30.09.2025	2150.962	2121.997	102.983	33776.7
Итого:	62.450	61.645	2.927	720.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.09.2025 0:00:00 - 30.09.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: ВКТ-7 Заводской номер: 00115028
Точка измерения: ТВ1; Ресурс: ТС

Подача: Счетчик воды: ПРЭМ SN 334995
Обратка: ПРЭМ SN 333703

Датчик температуры: КТСП-Н SN 32048г
КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.09.2025	26.04	24.64	1.40	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
02.09.2025	26.90	25.37	1.53	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
03.09.2025	27.08	25.65	1.43	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
04.09.2025	27.38	25.86	1.52	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
05.09.2025	27.42	25.95	1.47	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
06.09.2025	27.86	26.34	1.52	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
07.09.2025	28.11	26.44	1.67	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
08.09.2025	27.44	25.86	1.58	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
09.09.2025	27.23	25.63	1.60	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
10.09.2025	26.66	25.12	1.54	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
11.09.2025	26.65	25.02	1.63	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
12.09.2025	26.14	24.46	1.68	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
13.09.2025	26.10	24.61	1.49	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
14.09.2025	26.35	24.77	1.58	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
15.09.2025	26.18	24.60	1.58	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
16.09.2025	25.91	24.36	1.55	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
17.09.2025	26.44	24.77	1.67	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
18.09.2025	26.72	25.13	1.59	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
19.09.2025	26.42	24.89	1.53	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
20.09.2025	27.01	25.42	1.59	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
21.09.2025	26.74	25.26	1.48	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
22.09.2025	27.07	25.56	1.51	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
23.09.2025	27.40	25.95	1.45	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
24.09.2025	27.47	26.01	1.46	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
25.09.2025	26.48	24.98	1.50	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
26.09.2025	31.86	21.28	10.58	3.46	3.34	3.53	3.46	3.34	3.53	0.12	9.00	5.00	0.036	24.0	0.0	*
27.09.2025	53.14	29.40	23.74	8.21	7.93	3.47	8.19	7.93	3.23	0.26	9.00	5.00	0.194	24.0	0.0	
28.09.2025	55.71	30.55	25.16	8.48	8.17	3.72	8.33	8.17	1.94	0.16	9.00	5.00	0.209	24.0	0.0	
29.09.2025	56.90	29.40	27.50	7.59	7.30	3.90	7.55	7.30	3.37	0.25	9.00	5.00	0.210	24.0	0.0	
30.09.2025	64.87	32.68	32.19	8.54	8.30	2.85	8.30	8.30	0.00	0.00	9.00	5.00	0.266	24.0	0.0	
Средние:	31.12	25.87	5.26	---	---	0.58	---	---	0.40	---	9.00	5.00	---	---	---	
Итого:	---	---	---	36.28	35.04	---	35.83	35.04	---	0.79	---	---	0.915	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	Т	Т	Т	Гкал	ч	ч
31.08.2025	8908.19	8940.77	8674.22	8842.64	-168.42	259.034	23435.0	1.0
30.09.2025	8944.47	8975.81	8710.05	8877.68	-167.63	259.949	24155.0	1.0
Итого:	36.28	35.04	35.83	35.04	0.79	0.915	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации