

Отчет о суточных параметрах ГВС
(01.09.2025 0:00:00 - 30.09.2025 0:00:00)

Объект: Пермский край, Пермь г, Чистопольская ул, д. 18 (ООО "ЗУК")

Прибор: Карат-30X Заводской номер: 89503624

Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	t2	dt	V1	V2	M1	M2	P1	P2	Q1	Q2	Q3	Траб	NS	gNSCode
	°C	°C	°C	м3	м3	т	т	кгс/см2	кгс/см2	Гкал	Гкал	Гкал	ч		
01.09.2025	53.90	40.63	13.27	17.121	11.223	16.888	11.139	4.34	4.28	0.662	0.285	0.377	24.0		Ok
02.09.2025	55.13	41.23	13.91	16.640	11.151	16.404	11.065	4.31	4.25	0.662	0.290	0.372	24.0		Ok
03.09.2025	54.89	41.09	13.81	17.054	11.110	16.815	11.025	4.29	4.24	0.672	0.287	0.385	24.0		Ok
04.09.2025	53.92	40.53	13.39	16.685	11.074	16.459	10.992	4.46	4.40	0.643	0.280	0.363	24.0		Ok
05.09.2025	53.68	40.47	13.21	16.987	11.045	16.758	10.963	4.54	4.48	0.652	0.279	0.373	24.0		Ok
06.09.2025	54.01	40.37	13.65	15.837	10.924	15.622	10.844	4.60	4.54	0.612	0.275	0.337	24.0		Ok
07.09.2025	53.18	40.23	12.95	17.355	10.822	17.126	10.743	4.15	4.08	0.656	0.271	0.385	24.0		Ok
08.09.2025	53.84	40.59	13.25	17.513	10.750	17.275	10.670	4.29	4.22	0.675	0.273	0.402	24.0		Ok
09.09.2025	53.34	40.19	13.15	17.178	10.770	16.949	10.691	4.27	4.20	0.655	0.269	0.386	24.0		Ok
10.09.2025	53.51	40.34	13.17	17.190	11.047	16.959	10.966	4.25	4.17	0.657	0.278	0.379	24.0		Ok
11.09.2025	53.33	40.14	13.19	17.202	11.022	16.973	10.942	4.40	4.32	0.654	0.275	0.379	24.0		Ok
12.09.2025	53.58	40.12	13.46	17.312	11.159	17.079	11.078	4.50	4.44	0.664	0.278	0.386	24.0		Ok
13.09.2025	53.79	40.06	13.73	16.639	11.227	16.413	11.146	4.59	4.53	0.641	0.279	0.362	24.0		Ok
14.09.2025	53.05	39.89	13.16	19.359	11.153	19.102	11.073	4.24	4.17	0.735	0.275	0.460	24.0		Ok
15.09.2025	53.54	39.90	13.64	16.973	11.138	16.745	11.058	4.38	4.31	0.817	0.386	0.431	24.0		Ok
16.09.2025	54.37	40.63	13.74	16.733	11.007	16.502	10.925	4.64	4.57	0.819	0.389	0.429	24.0		Ok
17.09.2025	53.67	40.13	13.54	16.848	11.132	16.621	11.051	4.53	4.47	0.814	0.388	0.425	24.0		Ok
18.09.2025	53.52	40.06	13.47	16.674	11.151	16.450	11.070	4.61	4.55	0.803	0.388	0.415	24.0		Ok
19.09.2025	53.81	40.17	13.64	16.826	11.119	16.598	11.038	4.63	4.57	0.815	0.388	0.427	24.0		Ok
20.09.2025	53.59	40.37	13.22	18.099	11.082	17.855	11.001	4.68	4.62	0.873	0.389	0.484	24.0		Ok
21.09.2025	53.52	40.27	13.25	19.297	10.970	19.038	10.890	4.32	4.24	0.929	0.384	0.545	24.0		Ok
22.09.2025	53.20	40.14	13.06	17.639	11.002	17.405	10.922	4.41	4.34	0.843	0.384	0.459	24.0		Ok
23.09.2025	56.57	42.19	14.39	16.423	11.094	16.177	11.004	4.57	4.51	0.839	0.409	0.430	24.0		Ok
24.09.2025	55.84	42.09	13.75	17.337	11.052	17.084	10.963	4.37	4.31	0.873	0.407	0.466	24.0		Ok
25.09.2025	55.96	42.34	13.62	17.505	11.047	17.249	10.957	4.53	4.47	0.884	0.409	0.475	24.0		Ok
26.09.2025	55.75	41.92	13.83	16.769	11.146	16.525	11.057	4.50	4.44	0.845	0.408	0.436	24.0		Ok
27.09.2025	56.85	42.50	14.35	16.631	11.156	16.380	11.064	4.60	4.54	0.854	0.415	0.439	24.0		Ok
28.09.2025	56.78	41.42	15.36	17.281	10.435	17.019	10.351	4.14	4.08	0.890	0.383	0.507	24.0	*	HC Vmin
29.09.2025	56.27	42.10	14.17	17.081	11.307	16.828	11.215	4.26	4.20	0.867	0.417	0.450	24.0		Ok
30.09.2025	57.20	42.29	14.91	17.661	10.904	17.392	10.815	4.60	4.54	0.912	0.403	0.509	24.0		Ok
Средние:	54.45	40.81	13.64	---	---	---	---	4.43	4.37	---	---	---	---		
Итого:	---	---	---	515.849	331.219	508.689	328.717	---	---	22.915	10.242	12.673	720.0		

Дата	V1	V2	M1	M2	Q1	Q2	Q3	Траб
	м3	м3	т	т	Гкал	Гкал	Гкал	ч
31.08.2025	3849.221	2389.217	3792.932	2370.223	180.801	78.178	102.623	6488.2
30.09.2025	4365.070	2720.435	4301.621	2698.940	203.716	88.421	115.295	7208.2
Итого:	515.849	331.218	508.689	328.717	22.915	10.242	12.673	720.0

Представитель абонента

Представитель энергоснабжающей организации