

Отчет о суточных параметрах ГВС  
(01.10.2025 0:00:00 - 31.10.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")  
Прибор: Карат-30X Заводской номер: 11432221  
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.10.2025	55.85	2.600	2.562	3.75	0.130	24.0		Ok
02.10.2025	54.37	1.992	1.964	3.83	0.097	24.0		Ok
03.10.2025	54.00	2.098	2.069	3.91	0.101	24.0		Ok
04.10.2025	52.72	2.116	2.089	3.86	0.100	24.0		Ok
05.10.2025	54.68	2.637	2.600	3.42	0.129	24.0		Ok
06.10.2025	54.34	1.862	1.836	3.62	0.091	24.0		Ok
07.10.2025	54.83	2.510	2.475	3.68	0.123	24.0		Ok
08.10.2025	54.12	2.020	1.992	3.88	0.098	23.0		Ok
09.10.2025	56.34	2.271	2.237	3.74	0.115	24.0		Ok
10.10.2025	54.48	2.166	2.136	3.67	0.106	24.0		Ok
11.10.2025	51.47	2.334	2.305	3.73	0.107	24.0		Ok
12.10.2025	50.46	2.074	2.049	3.46	0.093	24.0		Ok
13.10.2025	48.88	1.030	1.018	3.70	0.045	24.0		Ok
14.10.2025	50.49	0.905	0.894	3.94	0.041	24.0		Ok
15.10.2025	51.35	0.980	0.968	4.01	0.045	24.0		Ok
16.10.2025	50.89	0.969	0.957	4.03	0.044	24.0		Ok
17.10.2025	51.14	0.792	0.782	4.18	0.036	24.0		Ok
18.10.2025	50.89	0.926	0.915	4.06	0.042	24.0		Ok
19.10.2025	50.55	1.135	1.121	3.66	0.051	24.0		Ok
20.10.2025	48.54	0.825	0.816	3.91	0.036	24.0		Ok
21.10.2025	50.34	0.959	0.948	4.14	0.043	24.0		Ok
22.10.2025	51.03	0.934	0.923	4.06	0.042	24.0		Ok
23.10.2025	53.11	1.127	1.112	3.96	0.053	24.0		Ok
24.10.2025	54.15	3.163	3.120	3.98	0.153	24.0		Ok
25.10.2025	54.41	1.811	1.786	4.12	0.088	24.0		Ok
26.10.2025	53.39	1.837	1.813	3.91	0.088	24.0		Ok
27.10.2025	53.08	1.785	1.762	4.08	0.085	24.0		Ok
28.10.2025	53.81	2.175	2.146	4.18	0.105	24.0		Ok
29.10.2025	53.63	1.722	1.699	4.17	0.083	24.0		Ok
30.10.2025	53.41	1.773	1.749	4.14	0.085	24.0		Ok
31.10.2025	52.67	1.821	1.797	4.11	0.086	24.0		Ok
Средние:	52.69	---	---	3.90	---	---		
Итого:	---	53.349	52.643	---	2.538	743.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
30.09.2025	2150.962	2121.997	102.983	33776.7
31.10.2025	2204.311	2174.640	105.522	34519.7
Итого:	53.349	52.643	2.538	743.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.10.2025 0:00:00 - 31.10.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

ПРЭМ SN 334995

Подача:

ПРЭМ SN 333703

Обратка:

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.10.2025	65.23	34.34	30.89	9.00	8.75	2.82	8.83	8.75	0.91	0.08	9.00	5.00	0.274	24.0	0.0	
02.10.2025	67.30	37.65	29.65	11.12	10.88	2.18	10.88	10.88	0.00	0.00	9.00	5.00	0.326	24.0	0.0	
03.10.2025	64.09	35.82	28.27	10.22	9.96	2.58	10.00	9.96	0.40	0.04	9.00	5.00	0.286	24.0	0.0	
04.10.2025	63.60	35.80	27.80	10.22	9.95	2.68	10.00	9.95	0.50	0.05	9.00	5.00	0.279	24.0	0.0	
05.10.2025	63.99	36.22	27.77	10.41	10.15	2.53	10.17	10.15	0.20	0.02	9.00	5.00	0.282	24.0	0.0	
06.10.2025	63.89	36.26	27.63	9.96	9.70	2.64	9.77	9.70	0.72	0.07	9.00	5.00	0.271	24.0	0.0	
07.10.2025	63.51	35.15	28.36	9.30	9.05	2.72	9.10	9.05	0.55	0.05	9.00	5.00	0.261	24.0	0.0	
08.10.2025	64.74	35.27	29.47	8.79	8.55	2.77	8.61	8.55	0.70	0.06	9.00	5.00	0.253	24.0	0.0	
09.10.2025	65.44	34.54	30.90	8.74	8.51	2.67	8.52	8.51	0.12	0.01	9.00	5.00	0.264	24.0	0.0	
10.10.2025	65.74	38.57	27.17	11.72	11.46	2.24	11.48	11.46	0.17	0.02	9.00	5.00	0.311	24.0	0.0	
11.10.2025	64.59	37.50	27.09	11.17	10.91	2.36	10.93	10.91	0.18	0.02	9.00	5.00	0.295	24.0	0.0	
12.10.2025	64.22	35.83	28.39	10.72	10.47	2.36	10.48	10.47	0.10	0.01	9.00	5.00	0.296	24.0	0.0	
13.10.2025	65.79	38.05	27.74	12.81	12.54	2.13	12.57	12.54	0.24	0.03	9.00	5.00	0.352	24.0	0.0	
14.10.2025	65.59	38.65	26.94	12.61	12.34	2.16	12.37	12.34	0.24	0.03	9.00	5.00	0.334	24.0	0.0	
15.10.2025	66.58	40.44	26.14	13.76	13.48	2.06	13.52	13.48	0.30	0.04	9.00	5.00	0.352	24.0	0.0	
16.10.2025	66.46	40.25	26.21	13.14	12.84	2.31	12.90	12.82	0.62	0.08	9.00	5.00	0.339	24.0	0.0	
17.10.2025	66.87	39.77	27.10	12.20	11.90	2.49	11.96	11.90	0.50	0.06	9.00	5.00	0.325	24.0	0.0	
18.10.2025	65.03	36.69	28.34	10.44	10.15	2.82	10.20	10.15	0.49	0.05	9.00	5.00	0.288	24.0	0.0	
19.10.2025	65.74	37.69	28.05	11.12	10.83	2.64	10.88	10.83	0.46	0.05	9.00	5.00	0.306	24.0	0.0	
20.10.2025	65.74	37.22	28.52	10.81	10.52	2.72	10.57	10.52	0.47	0.05	9.00	5.00	0.303	24.0	0.0	
21.10.2025	65.10	36.19	28.91	10.43	10.15	2.72	10.19	10.15	0.39	0.04	9.00	5.00	0.294	24.0	0.0	
22.10.2025	66.22	38.52	27.70	11.97	11.67	2.54	11.73	11.67	0.51	0.06	9.00	5.00	0.325	24.0	0.0	
23.10.2025	66.89	39.60	27.29	12.54	12.22	2.58	12.30	12.22	0.65	0.08	9.00	5.00	0.336	24.0	0.0	
24.10.2025	65.98	38.58	27.40	11.60	11.30	2.62	11.36	11.30	0.53	0.06	9.00	5.00	0.311	24.0	0.0	
25.10.2025	65.39	37.67	27.72	11.07	10.77	2.75	10.83	10.77	0.56	0.06	9.00	5.00	0.301	24.0	0.0	
26.10.2025	65.49	38.01	27.48	11.13	10.84	2.64	10.89	10.84	0.46	0.05	9.00	5.00	0.299	24.0	0.0	
27.10.2025	65.27	37.11	28.16	10.66	10.36	2.85	10.42	10.36	0.58	0.06	9.00	5.00	0.294	24.0	0.0	
28.10.2025	65.89	38.69	27.20	11.68	11.39	2.51	11.44	11.39	0.44	0.05	9.00	5.00	0.310	24.0	0.0	
29.10.2025	66.56	39.54	27.02	12.23	11.91	2.65	11.99	11.91	0.67	0.08	9.00	5.00	0.325	24.0	0.0	
30.10.2025	65.94	39.11	26.83	11.66	11.36	2.61	11.42	11.36	0.53	0.06	9.00	5.00	0.306	24.0	0.0	
31.10.2025	65.57	37.54	28.03	10.82	10.52	2.81	10.58	10.52	0.57	0.06	9.00	5.00	0.297	24.0	0.0	
Средние:	65.43	37.49	27.94	---	---	2.55	---	---	0.44	---	9.00	5.00	---	---	---	
Итого:	---	---	---	344.05	335.43	---	336.89	335.41	---	1.48	---	---	9.395	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
30.09.2025	8944.47	8975.81	8710.05	8877.68	-167.63	259.949	24155.0	1.0
31.10.2025	9288.52	9311.24	9046.94	9213.09	-166.15	269.344	24899.0	1.0
Итого:	344.05	335.43	336.89	335.41	1.48	9.395	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации