

Отчет о суточных параметрах
(01.10.2025 0:00:00 - 31.10.2025 0:00:00)

Объект: Пермский край, Пермь г, Чистопольская ул, д. 18 (ООО "ЗУК")
Прибор: ТМК-Н13 Заводской номер: 2261
Точка измерения: ТС2; Ресурс: ТС

Схема измерений: Закрытая система, ПР в подающем ТП и обратном ТП (измерение Q по G3)

| Дата | t3 | t4 | M3 | M4 | P3 | P4 | Qo | txв | BHP | NS |
|------------|-------|-------|---------|---------|---------|---------|--------|------|-------|----|
| | °C | °C | т | т | кгс/см2 | кгс/см2 | Гкал | °C | ч | |
| 01.10.2025 | 62.80 | 42.30 | 75.43 | 76.32 | 8.00 | 8.00 | 1.549 | 5.00 | 24.0 | |
| 02.10.2025 | 64.00 | 43.50 | 79.04 | 79.92 | 8.00 | 8.00 | 1.617 | 5.00 | 24.0 | |
| 03.10.2025 | 61.90 | 42.90 | 82.00 | 82.97 | 8.00 | 8.00 | 1.552 | 5.00 | 24.0 | |
| 04.10.2025 | 61.60 | 43.00 | 82.82 | 83.86 | 8.00 | 8.00 | 1.539 | 5.00 | 24.0 | |
| 05.10.2025 | 61.90 | 43.50 | 84.28 | 85.59 | 8.00 | 8.00 | 1.548 | 5.00 | 24.0 | |
| 06.10.2025 | 62.20 | 43.40 | 82.10 | 83.86 | 8.00 | 8.00 | 1.539 | 5.00 | 24.0 | |
| 07.10.2025 | 61.70 | 42.90 | 78.34 | 80.78 | 8.00 | 8.00 | 1.466 | 5.00 | 24.0 | |
| 08.10.2025 | 62.30 | 42.60 | 73.82 | 76.21 | 8.00 | 8.00 | 1.450 | 5.00 | 24.0 | |
| 09.10.2025 | 63.70 | 43.40 | 75.05 | 77.60 | 8.00 | 8.00 | 1.519 | 5.00 | 24.0 | |
| 10.10.2025 | 63.50 | 45.30 | 88.21 | 90.95 | 8.00 | 8.00 | 1.602 | 5.00 | 24.0 | |
| 11.10.2025 | 61.90 | 43.50 | 80.56 | 83.35 | 8.00 | 8.00 | 1.485 | 5.00 | 24.0 | |
| 12.10.2025 | 61.70 | 43.10 | 81.18 | 84.14 | 8.00 | 8.00 | 1.502 | 5.00 | 24.0 | |
| 13.10.2025 | 62.90 | 44.80 | 90.47 | 94.02 | 8.00 | 8.00 | 1.640 | 5.00 | 24.0 | * |
| 14.10.2025 | 61.30 | 43.30 | 84.36 | 87.45 | 7.70 | 7.70 | 1.574 | 4.80 | 23.1 | * |
| 15.10.2025 | 63.50 | 45.60 | 93.64 | 96.84 | 8.00 | 8.00 | 1.678 | 5.00 | 24.0 | * |
| 16.10.2025 | 63.60 | 45.90 | 95.97 | 99.21 | 8.00 | 8.00 | 1.693 | 5.00 | 24.0 | * |
| 17.10.2025 | 64.10 | 46.70 | 98.83 | 101.56 | 8.00 | 8.00 | 1.726 | 5.00 | 24.0 | |
| 18.10.2025 | 62.20 | 44.00 | 85.41 | 88.42 | 8.00 | 8.00 | 1.552 | 5.00 | 24.0 | |
| 19.10.2025 | 62.80 | 44.90 | 90.48 | 93.74 | 8.00 | 8.00 | 1.617 | 5.00 | 24.0 | |
| 20.10.2025 | 62.50 | 44.30 | 86.96 | 90.21 | 8.00 | 8.00 | 1.582 | 5.00 | 24.0 | |
| 21.10.2025 | 61.60 | 43.40 | 84.90 | 87.61 | 8.00 | 8.00 | 1.545 | 5.00 | 24.0 | |
| 22.10.2025 | 63.00 | 45.40 | 96.03 | 98.70 | 8.00 | 8.00 | 1.686 | 5.00 | 24.0 | |
| 23.10.2025 | 63.60 | 45.10 | 99.89 | 102.52 | 8.00 | 8.00 | 1.836 | 5.00 | 24.0 | |
| 24.10.2025 | 62.60 | 44.70 | 94.01 | 96.89 | 8.00 | 8.00 | 1.684 | 5.00 | 24.0 | |
| 25.10.2025 | 62.10 | 44.00 | 90.25 | 93.05 | 8.00 | 8.00 | 1.633 | 5.00 | 24.0 | |
| 26.10.2025 | 62.10 | 40.40 | 90.79 | 93.68 | 8.00 | 8.00 | 1.962 | 5.00 | 24.0 | * |
| 27.10.2025 | 61.80 | 43.50 | 86.42 | 89.03 | 8.00 | 8.00 | 1.579 | 5.00 | 24.0 | |
| 28.10.2025 | 62.80 | 45.40 | 95.00 | 97.76 | 8.00 | 8.00 | 1.655 | 5.00 | 24.0 | |
| 29.10.2025 | 63.70 | 46.30 | 97.66 | 100.14 | 8.00 | 8.00 | 1.698 | 5.00 | 24.0 | |
| 30.10.2025 | 63.60 | 46.00 | 94.81 | 97.03 | 8.00 | 8.00 | 1.671 | 5.00 | 24.0 | |
| 31.10.2025 | 63.10 | 44.60 | 86.71 | 88.81 | 8.00 | 8.00 | 1.602 | 5.00 | 24.0 | |
| Средние: | 62.65 | 44.12 | --- | --- | 7.99 | 7.99 | --- | 4.99 | --- | |
| Итого: | --- | --- | 2705.43 | 2782.21 | --- | --- | 49.980 | --- | 743.0 | |

| Дата | M3 | M4 | Qo | BHP |
|------------|-----------|-----------|----------|---------|
| | т | т | Гкал | ч |
| 30.09.2025 | 168944.35 | 165559.48 | 4391.800 | 50338.3 |
| 31.10.2025 | 171649.78 | 168341.69 | 4441.780 | 51081.3 |
| Итого: | 2705.43 | 2782.21 | 49.980 | 743.0 |

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.10.2025 0:00:00 - 31.10.2025 0:00:00)

Объект: Пермский край, Пермь г, Чистопольская ул, д. 18 (ООО "ЗУК")

Прибор: Карат-30X Заводской номер: 89503624

Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

| Дата | t1 °C | t2 °C | dt °C | V1 м3 | V2 м3 | M1 т | M2 т | P1 кгс/см2 | P2 кгс/см2 | Q1 Гкал | Q2 Гкал | Q3 Гкал | Траб ч | NS | gNSCode |
|------------|----------|----------|----------|----------|----------|---------|---------|---------------|---------------|------------|------------|------------|-----------|----|---------|
| 01.10.2025 | 56.95 | 42.18 | 14.76 | 16.709 | 10.833 | 16.457 | 10.745 | 4.48 | 4.42 | 0.857 | 0.400 | 0.457 | 24.0 | | Ok |
| 02.10.2025 | 57.81 | 42.52 | 15.29 | 16.337 | 10.659 | 16.084 | 10.571 | 4.55 | 4.49 | 0.852 | 0.397 | 0.455 | 24.0 | * | HC Vmin |
| 03.10.2025 | 56.06 | 41.77 | 14.29 | 17.178 | 10.706 | 16.926 | 10.621 | 4.62 | 4.57 | 0.869 | 0.390 | 0.478 | 24.0 | | Ok |
| 04.10.2025 | 55.43 | 41.65 | 13.78 | 16.437 | 10.731 | 16.202 | 10.647 | 4.57 | 4.51 | 0.820 | 0.390 | 0.430 | 24.0 | | Ok |
| 05.10.2025 | 55.51 | 41.42 | 14.09 | 17.111 | 10.700 | 16.864 | 10.616 | 4.16 | 4.10 | 0.856 | 0.386 | 0.470 | 24.0 | | Ok |
| 06.10.2025 | 54.18 | 40.62 | 13.56 | 16.312 | 10.599 | 16.078 | 10.516 | 4.11 | 4.04 | 0.811 | 0.382 | 0.429 | 24.0 | * | HC G; H |
| 07.10.2025 | 56.28 | 41.80 | 14.48 | 17.268 | 11.112 | 17.013 | 11.024 | 4.40 | 4.33 | 0.876 | 0.406 | 0.471 | 24.0 | * | HC G |
| 08.10.2025 | 56.61 | 41.69 | 14.92 | 16.728 | 10.691 | 16.478 | 10.607 | 4.61 | 4.54 | 0.855 | 0.389 | 0.466 | 24.0 | * | HC G |
| 09.10.2025 | 57.75 | 42.37 | 15.38 | 16.201 | 10.538 | 15.949 | 10.452 | 4.45 | 4.38 | 0.846 | 0.390 | 0.455 | 24.0 | | Ok |
| 10.10.2025 | 57.18 | 42.11 | 15.07 | 15.616 | 10.395 | 15.378 | 10.311 | 4.38 | 4.31 | 0.806 | 0.383 | 0.423 | 24.0 | * | HC G |
| 11.10.2025 | 55.50 | 41.10 | 14.40 | 16.293 | 10.374 | 16.059 | 10.295 | 4.46 | 4.39 | 0.814 | 0.372 | 0.442 | 24.0 | * | HC G |
| 12.10.2025 | 55.00 | 40.59 | 14.41 | 16.958 | 10.281 | 16.717 | 10.204 | 4.19 | 4.12 | 0.841 | 0.363 | 0.478 | 24.0 | * | HC G |
| 13.10.2025 | 56.26 | 40.95 | 15.30 | 16.149 | 10.235 | 15.910 | 10.157 | 4.31 | 4.23 | 0.820 | 0.365 | 0.455 | 24.0 | | Ok |
| 14.10.2025 | 45.00 | 34.95 | 10.05 | 12.634 | 6.715 | 12.468 | 6.666 | 3.93 | 3.88 | 0.591 | 0.234 | 0.357 | 24.0 | * | HC G; H |
| 15.10.2025 | 57.19 | 41.96 | 15.23 | 15.252 | 10.448 | 15.019 | 10.364 | 4.51 | 4.44 | 0.788 | 0.383 | 0.405 | 24.0 | | Ok |
| 16.10.2025 | 57.58 | 42.24 | 15.34 | 16.233 | 10.479 | 15.982 | 10.394 | 4.54 | 4.48 | 0.845 | 0.387 | 0.458 | 24.0 | | Ok |
| 17.10.2025 | 57.95 | 42.39 | 15.56 | 16.144 | 10.460 | 15.893 | 10.374 | 4.68 | 4.62 | 0.844 | 0.388 | 0.456 | 24.0 | * | HC G |
| 18.10.2025 | 56.18 | 41.46 | 14.72 | 16.215 | 10.459 | 15.976 | 10.377 | 4.57 | 4.51 | 0.821 | 0.378 | 0.443 | 24.0 | | Ok |
| 19.10.2025 | 56.67 | 41.65 | 15.02 | 16.959 | 10.379 | 16.705 | 10.297 | 4.20 | 4.14 | 0.867 | 0.377 | 0.490 | 24.0 | | Ok |
| 20.10.2025 | 57.63 | 44.75 | 12.88 | 22.527 | 17.275 | 22.178 | 17.108 | 4.36 | 4.18 | 1.174 | 0.696 | 0.478 | 24.0 | | Ok |
| 21.10.2025 | 57.74 | 46.74 | 11.01 | 27.412 | 21.553 | 26.989 | 21.336 | 4.56 | 4.30 | 1.425 | 0.890 | 0.535 | 24.0 | * | HC G |
| 22.10.2025 | 58.74 | 47.51 | 11.24 | 26.229 | 21.619 | 25.811 | 21.393 | 4.49 | 4.23 | 1.388 | 0.909 | 0.479 | 24.0 | * | HC G |
| 23.10.2025 | 59.44 | 48.18 | 11.26 | 26.313 | 21.605 | 25.884 | 21.373 | 4.38 | 4.12 | 1.410 | 0.922 | 0.488 | 24.0 | * | HC G |
| 24.10.2025 | 58.82 | 49.01 | 9.81 | 27.507 | 21.600 | 27.068 | 21.359 | 4.41 | 4.15 | 1.457 | 0.940 | 0.517 | 24.0 | | Ok |
| 25.10.2025 | 58.09 | 48.42 | 9.67 | 27.628 | 21.602 | 27.197 | 21.367 | 4.55 | 4.29 | 1.444 | 0.928 | 0.517 | 24.0 | | Ok |
| 26.10.2025 | 58.09 | 48.42 | 9.67 | 28.262 | 21.591 | 27.822 | 21.356 | 4.35 | 4.09 | 1.476 | 0.927 | 0.549 | 24.0 | | Ok |
| 27.10.2025 | 58.32 | 48.51 | 9.80 | 27.433 | 21.579 | 27.002 | 21.344 | 4.51 | 4.24 | 1.440 | 0.928 | 0.512 | 24.0 | | Ok |
| 28.10.2025 | 58.51 | 46.89 | 11.63 | 23.762 | 16.994 | 23.385 | 16.815 | 4.66 | 4.48 | 1.255 | 0.718 | 0.538 | 24.0 | | Ok |
| 29.10.2025 | 57.91 | 43.53 | 14.38 | 17.538 | 10.781 | 17.263 | 10.688 | 4.68 | 4.62 | 0.919 | 0.412 | 0.508 | 24.0 | | Ok |
| 30.10.2025 | 57.79 | 44.77 | 13.03 | 17.851 | 12.738 | 17.568 | 12.617 | 4.55 | 4.45 | 0.942 | 0.508 | 0.434 | 24.0 | * | min; HC |
| 31.10.2025 | 57.97 | 44.97 | 13.00 | 18.546 | 12.511 | 18.257 | 12.394 | 4.62 | 4.53 | 0.969 | 0.497 | 0.472 | 24.0 | | Ok |
| Средние: | 56.78 | 43.45 | 13.32 | --- | --- | --- | --- | 4.45 | 4.33 | --- | --- | --- | --- | | |
| Итого: | --- | --- | --- | 599.742 | 418.242 | 590.583 | 414.388 | --- | --- | 30.978 | 16.436 | 14.542 | 744.0 | | |

| Дата | V1 м3 | V2 м3 | M1 т | M2 т | Q1 Гкал | Q2 Гкал | Q3 Гкал | Траб ч |
|------------|----------|----------|----------|----------|------------|------------|------------|-----------|
| 30.09.2025 | 4365.070 | 2720.435 | 4301.621 | 2698.940 | 203.716 | 88.421 | 115.295 | 7208.2 |
| 31.10.2025 | 4964.812 | 3138.677 | 4892.204 | 3113.328 | 234.694 | 104.857 | 129.837 | 7952.2 |
| Итого: | 599.742 | 418.242 | 590.583 | 414.388 | 30.978 | 16.436 | 14.542 | 744.0 |

Представитель абонента

Представитель энергоснабжающей организации