

Отчет о суточных параметрах  
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Волгодонская ул, д. 18 (ООО "УК "ЖКХ Кировский")

Прибор: ТМК-Н13 Заводской номер: 1182

Точка измерения: ТС1; Ресурс: ТС

Схема измерений: Закрытая система, ПР в подающем ТП и обратном ТП (измерение Q по G1)

Дата	t1	t2	M1	M2	P1	P2	Qo	txв	ВНР	NS
	°C	°C	т	т	кгс/см2	кгс/см2	Гкал	°C	ч	
01.11.2025	49.20	39.40	164.38	164.09	5.00	5.00	1.608	5.00	24.0	
02.11.2025	48.80	39.10	164.43	164.13	5.00	5.00	1.596	5.00	24.0	
03.11.2025	50.50	39.80	164.44	164.25	5.00	5.00	1.754	5.00	24.0	
04.11.2025	52.20	40.70	164.46	164.32	5.00	5.00	1.875	5.00	24.0	
05.11.2025	49.60	39.40	164.44	164.24	5.00	5.00	1.678	5.00	24.0	
06.11.2025	48.00	38.60	164.30	164.11	5.00	5.00	1.545	5.00	24.0	
07.11.2025	47.10	38.20	164.53	164.26	5.00	5.00	1.462	5.00	24.0	
08.11.2025	47.10	38.30	164.38	164.19	5.00	5.00	1.450	5.00	24.0	
09.11.2025	49.40	39.50	164.24	163.99	5.00	5.00	1.624	5.00	24.0	
10.11.2025	49.80	39.70	164.30	164.07	5.00	5.00	1.654	5.00	24.0	
11.11.2025	50.50	40.10	164.38	164.17	5.00	5.00	1.716	5.00	24.0	
12.11.2025	51.30	40.40	164.38	164.14	5.00	5.00	1.789	5.00	24.0	
13.11.2025	50.50	39.80	164.68	164.49	5.00	5.00	1.775	5.00	24.0	
14.11.2025	49.30	39.20	164.84	164.62	5.00	5.00	1.670	5.00	24.0	
15.11.2025	47.30	38.20	164.90	164.63	5.00	5.00	1.494	5.00	24.0	
16.11.2025	49.00	39.00	164.87	164.67	5.00	5.00	1.644	5.00	24.0	
17.11.2025	51.70	40.30	164.75	164.59	5.00	5.00	1.866	5.00	24.0	
18.11.2025	49.00	38.80	164.95	164.72	5.00	5.00	1.672	5.00	24.0	
19.11.2025	48.20	38.60	164.92	164.65	5.00	5.00	1.582	5.00	24.0	
20.11.2025	50.60	39.80	164.81	164.57	5.00	5.00	1.771	5.00	24.0	
21.11.2025	52.70	41.00	164.55	164.39	5.00	5.00	1.923	5.00	24.0	
22.11.2025	51.00	40.10	164.69	164.44	5.00	5.00	1.792	5.00	24.0	
23.11.2025	51.10	40.30	164.58	164.20	5.00	5.00	1.776	5.00	24.0	
24.11.2025	52.80	41.20	164.56	164.33	5.00	5.00	1.903	5.00	24.0	
25.11.2025	50.10	39.80	166.17	165.90	5.00	5.00	1.700	5.00	24.0	
26.11.2025	50.20	39.80	167.48	167.19	5.00	5.00	1.736	5.00	24.0	
27.11.2025	52.20	41.00	167.35	167.14	5.00	5.00	1.870	5.00	24.0	
28.11.2025	50.20	39.70	167.35	167.11	5.00	5.00	1.743	5.00	24.0	
29.11.2025	49.10	39.20	167.57	167.33	5.00	5.00	1.657	5.00	24.0	
30.11.2025	48.80	39.00	167.57	167.30	5.00	5.00	1.629	5.00	24.0	
Средние:	49.91	39.60	---	---	5.00	5.00	---	5.00	---	
Итого:	---	---	4953.26	4946.22	---	---	50.953	---	720.0	

Дата	M1	M2	Qo	ВНР
	т	т	Гкал	ч
31.10.2025	388310.54	541546.96	3996.980	72924.1
30.11.2025	393263.81	546493.18	4047.933	73644.1
Итого:	4953.26	4946.22	50.953	720.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС  
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Волгодонская ул, д. 18 (ООО "УК "ЖКХ Кировский")

Прибор: ТМК-Н13 Заводской номер: 1182

Точка измерения: ТС2; Ресурс: ГВС

Схема измерений: ГВС

Дата	t3	M3	P3	Qo	txв	BHP	NS
	°C	т	кгс/см2	Гкал	°C	ч	
01.11.2025	150.00	0.00	5.00	0.000	5.00	0.0	*
02.11.2025	150.00	0.00	5.00	0.000	5.00	0.0	*
03.11.2025	134.90	4.43	5.00	0.492	5.00	11.7	*
04.11.2025	144.80	1.72	5.00	0.191	5.00	3.9	*
05.11.2025	145.10	0.56	5.00	0.068	5.00	4.6	*
06.11.2025	149.80	0.02	5.00	0.002	5.00	0.3	*
07.11.2025	150.00	0.00	5.00	0.000	5.00	0.0	*
08.11.2025	150.00	0.00	5.00	0.000	5.00	0.0	*
09.11.2025	150.00	0.00	5.00	0.000	5.00	0.0	*
10.11.2025	150.00	0.00	5.00	0.000	5.00	0.0	*
11.11.2025	150.00	0.00	5.00	0.000	5.00	0.0	*
12.11.2025	108.00	5.69	5.00	0.324	5.00	11.4	*
13.11.2025	62.20	8.61	5.00	0.494	5.00	23.6	*
14.11.2025	60.40	9.21	5.00	0.518	5.00	24.0	*
15.11.2025	124.40	1.64	5.00	0.093	5.00	6.8	*
16.11.2025	58.70	8.35	5.00	0.458	5.00	24.0	*
17.11.2025	61.50	7.25	5.00	0.420	5.00	24.0	*
18.11.2025	58.90	8.49	5.00	0.467	5.00	24.0	*
19.11.2025	60.90	8.98	5.00	0.510	5.00	24.0	*
20.11.2025	61.40	8.41	5.00	0.481	5.00	24.0	*
21.11.2025	64.10	8.48	5.00	0.491	5.00	23.6	*
22.11.2025	71.40	8.43	5.00	0.471	5.00	20.8	*
23.11.2025	59.60	8.89	5.00	0.498	5.00	24.0	*
24.11.2025	60.60	7.81	5.00	0.441	5.00	24.0	*
25.11.2025	54.10	6.30	5.00	0.335	5.00	24.0	*
26.11.2025	59.10	7.12	5.00	0.402	5.00	24.0	*
27.11.2025	60.60	7.91	5.00	0.449	5.00	24.0	*
28.11.2025	59.80	7.60	5.00	0.426	5.00	24.0	*
29.11.2025	59.50	7.67	5.00	0.424	5.00	24.0	*
30.11.2025	58.50	7.84	5.00	0.433	5.00	24.0	*
Средние:	96.28	---	5.00	---	5.00	---	
Итого:	---	151.42	---	8.886	---	442.4	

Дата	M3	Qo	BHP
	т	Гкал	ч
31.10.2025	22062.62	1102.938	74013.5
30.11.2025	22214.04	1111.824	74455.9
Итого:	151.42	8.886	442.4

Представитель абонента

Представитель энергоснабжающей организации