

Отчет о суточных параметрах ГВС
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: Карат-30X Заводской номер: 11432221

Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1	V1	M1	P1	Q1	Траб	NS	gNSCode
	°C	м3	т	кгс/см2	Гкал	ч		
01.11.2025	52.44	1.668	1.647	4.18	0.078	24.0		Ok
02.11.2025	53.64	1.990	1.963	4.01	0.095	24.0		Ok
03.11.2025	53.19	2.044	2.017	4.12	0.097	24.0		Ok
04.11.2025	53.89	2.013	1.986	4.05	0.097	24.0		Ok
05.11.2025	54.13	2.306	2.275	4.21	0.112	24.0		Ok
06.11.2025	53.40	1.720	1.697	4.11	0.082	24.0		Ok
07.11.2025	53.57	2.240	2.210	4.14	0.107	24.0		Ok
08.11.2025	54.36	2.289	2.258	4.15	0.111	24.0		Ok
09.11.2025	54.23	2.669	2.632	3.86	0.130	24.0		Ok
10.11.2025	54.04	2.401	2.368	4.00	0.116	24.0		Ok
11.11.2025	52.96	1.627	1.606	4.09	0.077	24.0		Ok
12.11.2025	54.17	2.196	2.166	4.13	0.106	24.0		Ok
13.11.2025	53.41	1.872	1.847	4.19	0.089	24.0		Ok
14.11.2025	54.16	2.032	2.004	4.11	0.098	24.0		Ok
15.11.2025	52.25	2.085	2.058	3.80	0.097	24.0		Ok
16.11.2025	53.04	1.981	1.955	3.68	0.094	24.0		Ok
17.11.2025	52.77	1.908	1.883	3.87	0.090	24.0		Ok
18.11.2025	51.77	1.888	1.864	4.00	0.087	24.0		Ok
19.11.2025	53.15	2.079	2.052	4.01	0.099	24.0		Ok
20.11.2025	53.81	2.500	2.466	4.03	0.120	24.0		Ok
21.11.2025	54.38	2.343	2.311	4.04	0.114	24.0		Ok
22.11.2025	53.79	2.433	2.400	3.90	0.117	24.0		Ok
23.11.2025	53.68	2.174	2.145	3.70	0.104	24.0		Ok
24.11.2025	53.03	1.726	1.703	3.89	0.082	24.0		Ok
25.11.2025	52.67	2.119	2.092	4.05	0.100	24.0		Ok
26.11.2025	53.88	2.575	2.540	4.04	0.124	24.0		Ok
27.11.2025	53.66	1.817	1.793	4.07	0.087	24.0		Ok
28.11.2025	52.87	1.730	1.707	4.13	0.082	24.0		Ok
29.11.2025	52.95	2.030	2.003	3.99	0.096	24.0		Ok
30.11.2025	54.24	2.435	2.402	3.77	0.118	24.0		Ok
Средние:	53.45	---	---	4.01	---	---		
Итого:	---	62.890	62.050	---	3.009	720.0		

Дата	V1	M1	Q1	Траб
	м3	т	Гкал	ч
31.10.2025	2204.311	2174.640	105.522	34519.7
30.11.2025	2267.201	2236.690	108.530	35239.7
Итого:	62.890	62.050	3.009	720.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

Подача: ПРЭМ SN 334995

Обратка: ПРЭМ SN 333703

Схема измерений: Закрытая система отопления (Схема 3)

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.11.2025	65.67	37.12	28.55	10.67	10.38	2.76	10.43	10.38	0.48	0.05	9.00	5.00	0.296	24.0	0.0	
02.11.2025	64.80	35.99	28.81	10.04	9.76	2.83	9.80	9.76	0.41	0.04	9.00	5.00	0.282	24.0	0.0	
03.11.2025	68.28	36.82	31.46	10.61	10.34	2.58	10.37	10.34	0.29	0.03	9.00	5.00	0.327	24.0	0.0	
04.11.2025	71.85	38.27	33.58	10.98	10.73	2.30	10.74	10.73	0.09	0.01	9.00	5.00	0.360	24.0	0.0	
05.11.2025	67.92	37.50	30.42	10.78	10.50	2.63	10.54	10.50	0.38	0.04	9.00	5.00	0.323	24.0	0.0	
06.11.2025	65.53	37.02	28.51	11.33	11.03	2.68	11.09	11.03	0.54	0.06	9.00	5.00	0.317	24.0	0.0	
07.11.2025	66.58	39.11	27.47	12.41	12.10	2.53	12.17	12.10	0.58	0.07	9.00	5.00	0.332	24.0	0.0	
08.11.2025	66.32	38.74	27.58	11.82	11.51	2.66	11.58	11.51	0.61	0.07	9.00	5.00	0.321	24.0	0.0	
09.11.2025	65.24	36.31	28.93	10.14	9.86	2.80	9.90	9.86	0.40	0.04	9.00	5.00	0.285	24.0	0.0	
10.11.2025	66.02	36.79	29.23	10.56	10.27	2.78	10.32	10.27	0.49	0.05	9.00	5.00	0.302	24.0	0.0	
11.11.2025	66.98	36.71	30.27	10.52	10.24	2.70	10.28	10.24	0.39	0.04	9.00	5.00	0.311	24.0	0.0	
12.11.2025	68.58	37.13	31.45	10.66	10.39	2.57	10.42	10.39	0.29	0.03	9.00	5.00	0.328	24.0	0.0	
13.11.2025	68.23	36.63	31.60	10.36	10.09	2.64	10.12	10.09	0.30	0.03	9.00	5.00	0.320	24.0	0.0	
14.11.2025	66.49	36.73	29.76	10.64	10.35	2.76	10.40	10.35	0.48	0.05	9.00	5.00	0.308	24.0	0.0	
15.11.2025	65.17	36.26	28.91	10.53	10.25	2.69	10.31	10.25	0.58	0.06	9.00	5.00	0.299	24.0	0.0	
16.11.2025	65.82	35.02	30.80	9.91	9.62	2.97	9.67	9.62	0.52	0.05	9.00	5.00	0.297	24.0	0.0	
17.11.2025	69.80	36.50	33.30	10.33	10.08	2.45	10.09	10.08	0.10	0.01	9.00	5.00	0.333	24.0	0.0	
18.11.2025	65.34	34.60	30.74	9.53	9.26	2.87	9.29	9.26	0.32	0.03	9.00	5.00	0.287	24.0	0.0	
19.11.2025	65.28	36.35	28.93	10.88	10.58	2.80	10.64	10.58	0.57	0.06	9.00	5.00	0.306	24.0	0.0	
20.11.2025	67.67	36.43	31.24	10.63	10.35	2.67	10.39	10.35	0.39	0.04	9.00	5.00	0.324	24.0	0.0	
21.11.2025	71.00	37.58	33.42	10.82	10.56	2.43	10.58	10.56	0.19	0.02	9.00	5.00	0.357	24.0	0.0	
22.11.2025	67.98	36.48	31.50	10.35	10.08	2.64	10.11	10.08	0.30	0.03	9.00	5.00	0.318	24.0	0.0	
23.11.2025	67.71	36.50	31.21	10.65	10.37	2.66	10.41	10.37	0.38	0.04	9.00	5.00	0.325	24.0	0.0	
24.11.2025	71.25	39.45	31.80	12.22	11.95	2.23	11.98	11.95	0.25	0.03	9.00	5.00	0.381	24.0	0.0	
25.11.2025	68.13	39.76	28.37	12.85	12.55	2.36	12.61	12.55	0.48	0.06	9.00	5.00	0.357	24.0	0.0	
26.11.2025	67.73	38.92	28.81	12.53	12.22	2.51	12.29	12.22	0.57	0.07	9.00	5.00	0.353	24.0	0.0	
27.11.2025	70.32	40.07	30.25	12.95	12.66	2.26	12.71	12.66	0.39	0.05	9.00	5.00	0.387	24.0	0.0	
28.11.2025	68.22	38.75	29.47	12.25	11.95	2.48	12.01	11.95	0.50	0.06	9.00	5.00	0.355	24.0	0.0	
29.11.2025	66.05	37.85	28.20	11.81	11.51	2.57	11.57	11.51	0.52	0.06	9.00	5.00	0.329	24.0	0.0	
30.11.2025	65.83	38.01	27.82	12.11	11.81	2.51	11.87	11.81	0.51	0.06	9.00	5.00	0.330	24.0	0.0	
Средние:	67.39	37.31	30.08	---	---	2.61	---	---	0.41	---	9.00	5.00	---	---	---	
Итого:	---	---	---	331.87	323.35	---	324.69	323.35	---	1.34	---	---	9.750	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.10.2025	9288.52	9311.24	9046.94	9213.09	-166.15	269.344	24899.0	1.0
30.11.2025	9620.39	9634.59	9371.63	9536.44	-164.81	279.094	25619.0	1.0
Итого:	331.87	323.35	324.69	323.35	1.34	9.750	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации