

Отчет о суточных параметрах ГВС
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Маршала Рыбалко ул, д. 49 (ТСЖ "МАРШАЛА РЫБАЛКО,49")

Прибор: ТМК-Н13 Заводской номер: 2317

Точка измерения: ТС1; Ресурс: ГВС

Схема измерений: Открытая система (по разнице) ПР в подающем ТП и обратном ТП

Дата	t1	t2	M1	M2	P1	P2	Qo	txв	ВНР	NS
	°C	°C	т	т	кгс/см2	кгс/см2	Гкал	°C	ч	
01.11.2025	60.70	44.40	38.60	28.59	5.00	5.00	1.013	5.00	24.0	
02.11.2025	59.40	43.70	38.73	28.52	5.00	5.00	0.988	5.00	24.0	
03.11.2025	62.10	44.70	38.96	28.50	5.00	5.00	1.086	5.00	24.0	
04.11.2025	63.50	45.50	40.24	28.31	5.00	5.00	1.198	5.00	24.0	
05.11.2025	60.40	44.00	39.51	28.42	5.00	5.00	1.054	5.00	24.0	
06.11.2025	60.10	43.60	39.78	28.43	5.00	5.00	1.085	5.00	24.0	
07.11.2025	62.60	45.10	37.99	28.79	5.00	5.00	1.027	5.00	24.0	
08.11.2025	61.50	44.60	38.11	28.75	5.00	5.00	1.002	5.00	24.0	
09.11.2025	58.80	43.50	41.21	27.99	5.00	5.00	1.097	5.00	24.0	*
10.11.2025	60.00	43.70	39.96	28.36	5.00	5.00	1.076	5.00	24.0	
11.11.2025	60.70	43.60	39.59	28.55	5.00	5.00	1.083	5.00	24.0	
12.11.2025	62.20	44.30	39.57	28.76	5.00	5.00	1.115	5.00	24.0	
13.11.2025	63.40	44.70	37.61	29.22	5.00	5.00	1.028	5.00	24.0	
14.11.2025	61.90	44.40	38.99	29.04	5.00	5.00	1.062	5.00	24.0	
15.11.2025	61.90	44.30	39.37	29.01	5.00	5.00	1.084	5.00	24.0	
16.11.2025	60.70	43.70	41.58	28.65	5.00	5.00	1.174	5.00	24.0	
17.11.2025	63.60	45.00	39.88	29.12	5.00	5.00	1.158	5.00	24.0	
18.11.2025	60.80	43.70	39.33	29.22	5.00	5.00	1.045	5.00	24.0	
19.11.2025	61.90	44.30	39.14	29.38	5.00	5.00	1.059	5.00	24.0	
20.11.2025	63.30	45.10	39.50	29.40	5.00	5.00	1.119	5.00	24.0	
21.11.2025	64.10	45.90	37.86	29.60	5.00	5.00	1.022	5.00	24.0	
22.11.2025	61.80	44.60	39.24	29.61	5.00	5.00	1.039	5.00	24.0	
23.11.2025	61.90	44.60	40.19	29.49	5.00	5.00	1.108	5.00	24.0	
24.11.2025	62.80	45.90	37.41	29.63	5.00	5.00	0.953	5.00	24.0	
25.11.2025	62.30	45.00	37.48	29.64	5.00	5.00	0.957	5.00	24.0	
26.11.2025	62.70	45.20	37.07	29.71	5.00	5.00	0.943	5.00	24.0	
27.11.2025	62.80	45.10	36.21	29.87	5.00	5.00	0.898	5.00	24.0	
28.11.2025	62.80	45.00	35.51	29.90	5.00	5.00	0.854	5.00	24.0	
29.11.2025	61.80	44.40	35.38	29.88	5.00	5.00	0.829	5.00	24.0	
30.11.2025	61.90	44.60	36.55	29.69	5.00	5.00	0.898	5.00	24.0	
Средние:	61.81	44.54	---	---	5.00	5.00	---	5.00	---	
Итого:	---	---	1160.55	872.03	---	---	31.054	---	720.0	

Дата	M1	M2	Qo	ВНР
	т	т	Гкал	ч
31.10.2025	33567.43	16868.81	1245.052	41711.8
30.11.2025	34727.99	17740.84	1276.106	42431.8
Итого:	1160.55	872.03	31.054	720.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.11.2025 0:00:00 - 30.11.2025 0:00:00)

Объект: Пермский край, Пермь г, Маршала Рыбалко ул, д. 49 (ТСЖ "МАРШАЛА РЫБАЛКО,49")
Прибор: ТМК-Н13 Заводской номер: 2317
Точка измерения: ТС2; Ресурс: ТС

Подача: ВПС SN 5017175
Обратка: ВПС SN 5017179

Датчик температуры:
КТПТР-01 SN 34537а
КТПТР-01 SN 34537

Схема измерений: Закрытая система, ПР в подающем ТП и обратном ТП (измерение Q по G3)

Дата	t3	t4	M3	M4	P3	P4	Qo	txв	BHP	NS
	°C	°C	т	т	кгс/см2	кгс/см2	Гкал	°C	ч	
01.11.2025	45.70	39.40	398.50	402.28	5.00	5.00	2.506	5.00	24.0	
02.11.2025	44.40	38.50	398.65	402.69	5.00	5.00	2.373	5.00	24.0	
03.11.2025	46.10	39.30	398.67	402.60	5.00	5.00	2.704	5.00	24.0	
04.11.2025	48.70	41.00	398.67	402.56	5.00	5.00	3.059	5.00	24.0	
05.11.2025	47.30	40.30	398.78	402.82	5.00	5.00	2.778	5.00	24.0	
06.11.2025	46.20	39.50	398.72	403.08	5.00	5.00	2.662	5.00	24.0	
07.11.2025	45.10	39.00	398.63	403.04	5.00	5.00	2.449	5.00	24.0	
08.11.2025	46.40	39.90	398.62	402.89	5.00	5.00	2.610	5.00	24.0	
09.11.2025	44.80	38.70	398.62	402.90	5.00	5.00	2.416	5.00	24.0	
10.11.2025	45.20	38.90	398.61	402.88	5.00	5.00	2.509	5.00	24.0	
11.11.2025	45.10	38.70	398.80	402.90	5.00	5.00	2.547	5.00	24.0	
12.11.2025	45.90	39.20	398.82	402.84	5.00	5.00	2.681	5.00	24.0	
13.11.2025	48.00	40.50	398.73	402.83	5.00	5.00	2.978	5.00	24.0	
14.11.2025	49.00	41.40	398.57	402.60	5.00	5.00	3.013	5.00	24.0	
15.11.2025	46.80	40.10	398.71	402.67	5.00	5.00	2.664	5.00	24.0	
16.11.2025	47.10	40.20	398.82	402.93	5.00	5.00	2.745	5.00	24.0	
17.11.2025	50.80	42.50	398.94	402.89	5.00	5.00	3.287	5.00	24.0	
18.11.2025	46.60	39.70	399.08	403.03	5.00	5.00	2.737	5.00	24.0	
19.11.2025	46.90	40.10	399.25	403.11	5.00	5.00	2.740	5.00	24.0	
20.11.2025	50.00	42.10	399.17	403.10	5.00	5.00	3.147	5.00	24.0	
21.11.2025	54.30	44.90	399.06	402.79	5.00	5.00	3.739	5.00	24.0	
22.11.2025	49.90	42.20	398.98	402.96	5.00	5.00	3.062	5.00	24.0	
23.11.2025	51.20	43.00	399.16	403.00	5.00	5.00	3.281	5.00	24.0	
24.11.2025	54.60	45.20	399.21	402.93	5.00	5.00	3.758	5.00	24.0	
25.11.2025	51.10	43.10	399.04	402.81	5.00	5.00	3.197	5.00	24.0	
26.11.2025	53.10	44.30	399.20	402.85	5.00	5.00	3.504	5.00	24.0	
27.11.2025	54.00	45.00	399.27	402.96	5.00	5.00	3.608	5.00	24.0	
28.11.2025	53.60	44.70	399.06	402.74	5.00	5.00	3.557	5.00	24.0	
29.11.2025	51.00	43.00	398.96	402.73	5.00	5.00	3.174	5.00	24.0	
30.11.2025	49.90	42.20	398.98	402.72	5.00	5.00	3.068	5.00	24.0	
Средние:	48.63	41.22	---	---	5.00	5.00	---	5.00	---	
Итого:	---	---	11966.27	12085.13	---	---	88.553	---	720.0	

Дата	M3	M4	Qo	BHP
	т	т	Гкал	ч
31.10.2025	463854.01	439422.49	4080.578	42042.6
30.11.2025	475820.28	451507.61	4169.131	42762.6
Итого:	11966.27	12085.13	88.553	720.0

Представитель абонента

Представитель энергоснабжающей организации