

Отчет о суточных параметрах ГВС
(01.12.2025 0:00:00 - 31.12.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 11432221
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.12.2025	54.23	2.215	2.185	3.85	0.107	24.0		Ok
02.12.2025	52.81	1.756	1.733	3.90	0.083	24.0		Ok
03.12.2025	53.66	1.940	1.914	3.98	0.093	24.0		Ok
04.12.2025	52.54	1.638	1.617	4.01	0.077	24.0		Ok
05.12.2025	53.79	1.860	1.835	4.01	0.089	24.0		Ok
06.12.2025	53.07	2.324	2.293	4.02	0.110	24.0		Ok
07.12.2025	54.01	2.365	2.333	3.75	0.114	24.0		Ok
08.12.2025	53.51	2.046	2.019	3.85	0.098	24.0		Ok
09.12.2025	53.14	1.643	1.621	3.99	0.078	24.0		Ok
10.12.2025	52.75	1.545	1.525	4.06	0.073	24.0		Ok
11.12.2025	54.44	2.189	2.159	4.16	0.107	24.0		Ok
12.12.2025	52.86	1.783	1.760	4.19	0.084	24.0		Ok
13.12.2025	52.88	1.669	1.647	4.08	0.079	24.0		Ok
14.12.2025	53.63	2.114	2.086	3.83	0.101	24.0		Ok
15.12.2025	53.73	1.708	1.685	3.99	0.082	24.0		Ok
16.12.2025	54.04	1.623	1.601	4.17	0.078	24.0		Ok
17.12.2025	52.84	1.493	1.474	4.11	0.070	24.0		Ok
18.12.2025	54.18	1.621	1.599	3.94	0.079	24.0		Ok
19.12.2025	54.52	2.238	2.207	4.10	0.109	24.0		Ok
20.12.2025	52.66	1.892	1.868	4.02	0.089	24.0		Ok
21.12.2025	53.91	1.798	1.774	3.74	0.087	24.0		Ok
22.12.2025	55.16	1.718	1.694	3.92	0.085	24.0		Ok
23.12.2025	53.21	1.248	1.232	4.08	0.059	24.0		Ok
24.12.2025	54.79	2.088	2.059	4.02	0.102	24.0		Ok
25.12.2025	54.05	1.641	1.619	3.88	0.079	24.0		Ok
26.12.2025	54.61	1.556	1.534	3.93	0.076	24.0		Ok
27.12.2025	54.44	2.186	2.156	3.92	0.107	24.0		Ok
28.12.2025	54.57	1.956	1.929	3.75	0.096	24.0		Ok
29.12.2025	54.31	2.001	1.973	3.93	0.097	24.0		Ok
30.12.2025	54.74	2.038	2.010	3.72	0.100	24.0		Ok
31.12.2025	54.98	2.743	2.704	3.30	0.135	24.0		Ok
Средние:	53.81	---	---	3.94	---	---		
Итого:	---	58.635	57.842	---	2.825	744.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
30.11.2025	2267.201	2236.690	108.530	35239.7
31.12.2025	2325.836	2294.532	111.355	35983.7
Итого:	58.635	57.842	2.825	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.12.2025 0:00:00 - 31.12.2025 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

ПРЭМ SN 334995

Подача:

ПРЭМ SN 333703

Обратка:

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.12.2025	66.91	38.83	28.08	12.51	12.20	2.51	12.27	12.20	0.57	0.07	9.00	5.00	0.344	24.0	0.0	
02.12.2025	66.82	38.47	28.35	12.08	11.78	2.51	11.84	11.78	0.51	0.06	9.00	5.00	0.336	24.0	0.0	
03.12.2025	67.89	39.39	28.50	12.57	12.27	2.42	12.33	12.27	0.49	0.06	9.00	5.00	0.354	24.0	0.0	
04.12.2025	68.26	39.59	28.67	12.73	12.44	2.30	12.49	12.44	0.40	0.05	9.00	5.00	0.359	24.0	0.0	
05.12.2025	68.63	39.42	29.21	12.44	12.15	2.36	12.20	12.15	0.41	0.05	9.00	5.00	0.356	24.0	0.0	
06.12.2025	73.69	42.47	31.22	13.86	13.59	1.97	13.62	13.54	0.59	0.08	9.00	5.00	0.427	24.0	0.0	
07.12.2025	82.38	45.46	36.92	14.08	13.91	1.21	13.60	13.70	-0.73	-0.10	9.00	5.00	0.504	24.0	0.0	
08.12.2025	88.37	44.46	43.91	12.09	12.00	0.75	11.65	11.94	-2.46	-0.29	9.00	5.00	0.512	24.0	0.0	
09.12.2025	95.63	46.60	49.03	12.59	12.57	0.16	12.11	12.38	-2.20	-0.27	9.00	5.00	0.594	24.0	0.0	
10.12.2025	85.94	44.99	40.95	12.98	12.87	0.85	12.52	12.73	-1.66	-0.21	9.00	5.00	0.514	24.0	0.0	
11.12.2025	80.66	41.99	38.67	12.25	12.10	1.23	11.99	12.10	-0.91	-0.11	9.00	5.00	0.463	24.0	0.0	
12.12.2025	79.72	42.62	37.10	12.65	12.49	1.27	12.30	12.43	-1.05	-0.13	9.00	5.00	0.456	24.0	0.0	
13.12.2025	74.29	40.83	33.46	12.55	12.36	1.53	12.31	12.36	-0.41	-0.05	9.00	5.00	0.414	24.0	0.0	
14.12.2025	77.96	42.01	35.95	12.66	12.48	1.43	12.39	12.48	-0.72	-0.09	9.00	5.00	0.448	24.0	0.0	
15.12.2025	85.35	45.20	40.15	13.30	13.19	0.83	12.82	13.02	-1.55	-0.20	9.00	5.00	0.518	24.0	0.0	
16.12.2025	97.13	48.63	48.50	13.27	13.27	0.00	12.79	13.03	-1.86	-0.24	9.00	5.00	0.622	24.0	0.0	
17.12.2025	99.22	50.27	48.95	13.78	13.80	-0.15	13.30	13.56	-1.94	-0.26	9.00	5.00	0.655	24.0	0.0	
18.12.2025	95.46	49.93	45.53	14.19	14.17	0.14	13.71	13.93	-1.59	-0.22	9.00	5.00	0.628	24.0	0.0	
19.12.2025	89.29	47.60	41.69	13.70	13.63	0.51	13.22	13.41	-1.43	-0.19	9.00	5.00	0.554	24.0	0.0	
20.12.2025	95.74	45.13	50.61	11.79	11.77	0.17	11.31	11.70	-3.39	-0.39	9.00	5.00	0.574	24.0	0.0	
21.12.2025	96.18	48.76	47.42	13.57	13.56	0.07	13.09	13.32	-1.74	-0.23	9.00	5.00	0.622	24.0	0.0	
22.12.2025	87.44	45.83	41.61	12.99	12.88	0.85	12.51	12.68	-1.35	-0.17	9.00	5.00	0.520	24.0	0.0	
23.12.2025	90.08	44.94	45.14	12.10	12.02	0.66	11.62	11.98	-3.05	-0.36	9.00	5.00	0.525	24.0	0.0	
24.12.2025	104.63	47.38	57.25	11.93	11.98	-0.42	11.40	11.85	-3.87	-0.45	9.00	5.00	0.655	24.0	0.0	
25.12.2025	110.29	50.00	60.29	12.59	12.71	-0.95	11.90	12.47	-4.68	-0.57	9.00	5.00	0.720	24.0	0.0	
26.12.2025	101.61	49.12	52.49	13.20	13.24	-0.30	12.72	13.00	-2.18	-0.28	9.00	5.00	0.670	24.0	0.0	
27.12.2025	91.22	45.41	45.81	12.69	12.62	0.55	12.21	12.51	-2.43	-0.30	9.00	5.00	0.559	24.0	0.0	
28.12.2025	84.50	42.57	41.93	12.18	12.06	0.99	11.72	12.06	-2.86	-0.34	9.00	5.00	0.490	24.0	0.0	
29.12.2025	91.93	46.00	45.93	13.03	12.97	0.46	12.55	12.80	-1.97	-0.25	9.00	5.00	0.577	24.0	0.0	
30.12.2025	99.44	46.93	52.51	12.26	12.26	0.00	11.78	12.06	-2.35	-0.28	9.00	5.00	0.620	24.0	0.0	
31.12.2025	96.72	47.74	48.98	13.01	13.00	0.08	12.53	12.76	-1.82	-0.23	9.00	5.00	0.618	24.0	0.0	
Средние:	86.88	44.79	42.09	---	---	0.84	---	---	-1.52	---	9.00	5.00	---	---	---	
Итого:	---	---	---	397.62	394.34	---	384.80	390.64	---	-5.84	---	---	16.208	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
30.11.2025	9620.39	9634.59	9371.63	9536.44	-164.81	279.094	25619.0	1.0
31.12.2025	10018.01	10028.93	9756.43	9927.08	-170.65	295.302	26363.0	1.0
Итого:	397.62	394.34	384.80	390.64	-5.84	16.208	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации