

Отчет о суточных параметрах ГВС  
(01.01.2026 0:00:00 - 31.01.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")  
Прибор: Карат-30X Заводской номер: 11432221  
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.01.2026	54.80	2.724	2.686	4.02	0.134	24.0		Ok
02.01.2026	52.55	1.569	1.549	4.26	0.074	24.0		Ok
03.01.2026	53.49	2.505	2.472	4.11	0.120	24.0		Ok
04.01.2026	54.75	2.388	2.355	4.06	0.117	24.0		Ok
05.01.2026	53.45	2.319	2.288	3.98	0.111	24.0		Ok
06.01.2026	53.41	1.812	1.788	3.94	0.087	24.0		Ok
07.01.2026	53.52	1.705	1.682	3.94	0.082	24.0		Ok
08.01.2026	53.91	2.347	2.315	3.99	0.113	24.0		Ok
09.01.2026	52.90	1.972	1.946	3.94	0.093	24.0		Ok
10.01.2026	53.32	1.715	1.692	3.89	0.082	24.0		Ok
11.01.2026	53.62	1.714	1.691	3.60	0.082	24.0		Ok
12.01.2026	52.04	1.503	1.484	3.81	0.070	24.0		Ok
13.01.2026	52.95	1.622	1.601	3.96	0.077	24.0		Ok
14.01.2026	54.18	1.687	1.664	3.83	0.082	24.0		Ok
15.01.2026	53.13	1.709	1.686	3.90	0.081	24.0		Ok
16.01.2026	54.10	2.163	2.134	4.00	0.105	24.0		Ok
17.01.2026	52.32	1.472	1.453	3.74	0.069	24.0		Ok
18.01.2026	52.19	1.583	1.563	3.46	0.074	24.0		Ok
19.01.2026	52.75	1.962	1.937	3.84	0.092	24.0		Ok
20.01.2026	53.44	1.776	1.752	3.93	0.085	24.0		Ok
21.01.2026	54.42	2.285	2.253	3.92	0.111	24.0		Ok
22.01.2026	53.16	1.743	1.720	3.72	0.083	24.0		Ok
23.01.2026	53.59	1.788	1.764	3.71	0.086	24.0		Ok
24.01.2026	53.31	1.932	1.906	3.24	0.092	24.0		Ok
25.01.2026	54.68	2.196	2.165	3.25	0.107	24.0		Ok
26.01.2026	53.60	1.530	1.509	3.53	0.073	24.0		Ok
27.01.2026	51.92	1.492	1.473	3.72	0.069	24.0		Ok
28.01.2026	53.05	1.982	1.956	3.80	0.094	24.0		Ok
29.01.2026	53.39	1.542	1.521	3.81	0.074	24.0		Ok
30.01.2026	53.99	1.634	1.612	3.85	0.079	24.0		Ok
31.01.2026	53.15	1.562	1.541	3.61	0.074	24.0		Ok
Средние:	53.39	---	---	3.82	---	---		
Итого:	---	57.933	57.160	---	2.770	744.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
31.12.2025	2325.836	2294.532	111.355	35983.7
31.01.2026	2383.769	2351.692	114.125	36727.7
Итого:	57.933	57.160	2.770	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.01.2026 0:00:00 - 31.01.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

ПРЭМ SN 334995

Подача:

ПРЭМ SN 333703

Обратка:

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.01.2026	87.15	44.21	42.94	12.55	12.46	0.72	12.07	12.40	-2.70	-0.33	9.00	5.00	0.517	24.0	0.0	
02.01.2026	88.92	44.39	44.53	12.48	12.39	0.72	12.00	12.33	-2.71	-0.33	9.00	5.00	0.535	24.0	0.0	
03.01.2026	92.39	44.49	47.90	12.13	12.07	0.50	11.65	12.07	-3.54	-0.42	9.00	5.00	0.558	24.0	0.0	
04.01.2026	84.74	43.52	41.22	12.64	12.54	0.79	12.26	12.48	-1.78	-0.22	9.00	5.00	0.505	24.0	0.0	
05.01.2026	77.30	40.73	36.57	12.32	12.15	1.39	12.08	12.15	-0.58	-0.07	9.00	5.00	0.443	24.0	0.0	
06.01.2026	79.67	41.31	38.36	12.38	12.24	1.14	12.13	12.24	-0.90	-0.11	9.00	5.00	0.466	24.0	0.0	
07.01.2026	88.09	43.61	44.48	12.29	12.20	0.73	11.81	12.20	-3.25	-0.39	9.00	5.00	0.526	24.0	0.0	
08.01.2026	84.36	43.01	41.35	12.39	12.29	0.81	11.98	12.29	-2.55	-0.31	9.00	5.00	0.496	24.0	0.0	
09.01.2026	75.85	40.70	35.15	12.35	12.17	1.47	12.11	12.17	-0.49	-0.06	9.00	5.00	0.425	24.0	0.0	
10.01.2026	78.66	41.10	37.56	12.22	12.07	1.24	11.98	12.07	-0.75	-0.09	9.00	5.00	0.450	24.0	0.0	
11.01.2026	86.04	44.29	41.75	12.82	12.72	0.78	12.37	12.59	-1.76	-0.22	9.00	5.00	0.517	24.0	0.0	
12.01.2026	93.09	46.11	46.98	12.69	12.65	0.32	12.21	12.45	-1.95	-0.24	9.00	5.00	0.574	24.0	0.0	
13.01.2026	100.29	49.65	50.64	13.39	13.44	-0.37	12.91	13.20	-2.22	-0.29	9.00	5.00	0.654	24.0	0.0	
14.01.2026	101.03	48.75	52.28	12.82	12.86	-0.31	12.34	12.62	-2.24	-0.28	9.00	5.00	0.648	24.0	0.0	
15.01.2026	100.87	48.37	52.50	12.56	12.60	-0.32	12.08	12.36	-2.29	-0.28	9.00	5.00	0.635	24.0	0.0	
16.01.2026	102.36	47.28	55.08	12.12	12.17	-0.41	11.64	11.93	-2.46	-0.29	9.00	5.00	0.645	24.0	0.0	
17.01.2026	98.46	45.70	52.76	12.16	12.17	-0.08	11.68	12.04	-3.04	-0.36	9.00	5.00	0.619	24.0	0.0	
18.01.2026	93.48	45.54	47.94	12.72	12.69	0.24	12.24	12.48	-1.94	-0.24	9.00	5.00	0.588	24.0	0.0	
19.01.2026	91.17	45.47	45.70	12.94	12.91	0.23	12.46	12.76	-2.38	-0.30	9.00	5.00	0.571	24.0	0.0	
20.01.2026	95.19	45.95	49.24	12.55	12.54	0.08	12.07	12.34	-2.21	-0.27	9.00	5.00	0.596	24.0	0.0	
21.01.2026	106.67	49.80	56.87	12.98	13.08	-0.77	12.38	12.84	-3.65	-0.46	9.00	5.00	0.706	24.0	0.0	
22.01.2026	110.68	50.26	60.42	12.65	12.80	-1.18	11.95	12.56	-4.98	-0.61	9.00	5.00	0.723	24.0	0.0	
23.01.2026	110.63	49.31	61.32	12.48	12.62	-1.12	11.81	12.38	-4.71	-0.57	9.00	5.00	0.727	24.0	0.0	
24.01.2026	110.52	49.01	61.51	12.49	12.64	-1.19	11.80	12.40	-4.96	-0.60	9.00	5.00	0.729	24.0	0.0	
25.01.2026	107.90	49.18	58.72	12.85	12.98	-1.01	12.21	12.74	-4.25	-0.53	9.00	5.00	0.718	24.0	0.0	
26.01.2026	106.11	49.89	56.22	12.98	13.11	-1.00	12.35	12.87	-4.12	-0.52	9.00	5.00	0.697	24.0	0.0	
27.01.2026	98.42	45.89	52.53	12.30	12.33	-0.24	11.82	12.16	-2.84	-0.34	9.00	5.00	0.622	24.0	0.0	
28.01.2026	93.40	45.85	47.55	12.73	12.76	-0.24	12.25	12.59	-2.74	-0.34	9.00	5.00	0.584	24.0	0.0	
29.01.2026	89.21	44.60	44.61	12.74	12.79	-0.39	12.26	12.67	-3.29	-0.41	9.00	5.00	0.545	24.0	0.0	
30.01.2026	86.84	44.89	41.95	12.87	12.94	-0.54	12.45	12.78	-2.62	-0.33	9.00	5.00	0.524	24.0	0.0	
31.01.2026	89.72	44.77	44.95	12.79	12.85	-0.47	12.38	12.75	-2.94	-0.37	9.00	5.00	0.557	24.0	0.0	
Средние:	93.85	45.73	48.12	---	---	0.05	---	---	-2.67	---	9.00	5.00	---	---	---	
Итого:	---	---	---	390.38	390.23	---	375.73	385.91	---	-10.18	---	---	18.100	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	Т	Т	Т	Гкал	ч	ч
31.12.2025	10018.01	10028.93	9756.43	9927.08	-170.65	295.302	26363.0	1.0
31.01.2026	10408.39	10419.16	10132.16	10312.99	-180.83	313.402	27107.0	1.0
Итого:	390.38	390.23	375.73	385.91	-10.18	18.100	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации