

Отчет о суточных параметрах ГВС
(01.02.2026 0:00:00 - 28.02.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 11432221
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.02.2026	54.68	2.468	2.434	3.33	0.121	24.0		Ok
02.02.2026	51.36	1.504	1.485	3.56	0.069	24.0		Ok
03.02.2026	52.94	2.052	2.025	3.92	0.097	24.0		Ok
04.02.2026	53.40	1.745	1.722	3.83	0.083	24.0		Ok
05.02.2026	54.16	2.464	2.430	3.69	0.119	24.0		Ok
06.02.2026	52.12	1.372	1.355	3.79	0.064	24.0		Ok
07.02.2026	52.36	1.606	1.585	3.70	0.075	24.0		Ok
08.02.2026	53.80	2.009	1.982	3.40	0.097	24.0		Ok
09.02.2026	53.82	2.152	2.123	3.72	0.104	24.0		Ok
10.02.2026	53.87	1.775	1.751	3.89	0.086	24.0		Ok
11.02.2026	53.54	1.998	1.971	3.86	0.096	24.0		Ok
12.02.2026	53.62	1.999	1.972	3.78	0.096	24.0		Ok
13.02.2026	53.30	1.642	1.620	3.82	0.078	24.0		Ok
14.02.2026	53.72	1.857	1.832	3.87	0.089	24.0		Ok
15.02.2026	52.87	1.777	1.754	3.54	0.084	24.0		Ok
16.02.2026	52.04	1.484	1.465	3.72	0.069	24.0		Ok
17.02.2026	54.05	1.739	1.715	3.82	0.084	24.0		Ok
18.02.2026	52.45	1.711	1.689	3.66	0.080	24.0		Ok
19.02.2026	53.01	1.963	1.937	3.60	0.093	24.0		Ok
20.02.2026	53.59	1.600	1.579	3.50	0.077	24.0		Ok
21.02.2026	54.47	2.653	2.616	3.67	0.129	24.0		Ok
22.02.2026	54.39	2.123	2.094	3.69	0.103	24.0		Ok
23.02.2026	54.41	1.914	1.888	3.27	0.093	24.0		Ok
24.02.2026	53.36	1.776	1.752	3.61	0.085	24.0		Ok
25.02.2026	53.34	2.434	2.402	3.67	0.116	24.0		Ok
26.02.2026	54.62	2.405	2.372	3.60	0.118	24.0		Ok
27.02.2026	53.77	1.925	1.899	3.79	0.093	24.0		Ok
28.02.2026	52.47	1.563	1.543	3.55	0.073	24.0		Ok
Средние:	---	---	---	3.67	---	---		
Итого:	---	53.710	52.992	---	2.569	672.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
31.01.2026	2383.769	2351.692	114.125	36727.7
28.02.2026	2437.479	2404.684	116.694	37399.7
Итого:	53.710	52.992	2.570	672.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.02.2026 0:00:00 - 28.02.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

ПРЭМ SN 334995

Подача:

ПРЭМ SN 333703

Обратка:

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.02.2026	96.77	48.70	48.07	13.71	13.68	0.22	13.23	13.44	-1.57	-0.21	9.00	5.00	0.638	24.0	0.0	
02.02.2026	90.48	43.18	47.30	11.01	11.07	-0.54	10.60	10.94	-3.16	-0.34	9.00	5.00	0.502	24.0	0.0	
03.02.2026	87.89	45.97	41.92	13.58	13.63	-0.37	13.10	13.39	-2.19	-0.29	9.00	5.00	0.553	24.0	0.0	
04.02.2026	87.55	43.95	43.60	11.93	12.00	-0.59	11.49	11.90	-3.51	-0.41	9.00	5.00	0.501	24.0	0.0	
05.02.2026	96.27	43.81	52.46	11.26	11.26	0.00	10.78	11.26	-4.36	-0.48	9.00	5.00	0.566	24.0	0.0	
06.02.2026	92.80	44.50	48.30	11.90	11.92	-0.17	11.42	11.91	-4.20	-0.49	9.00	5.00	0.554	24.0	0.0	
07.02.2026	92.01	44.77	47.24	12.16	12.19	-0.25	11.68	12.07	-3.28	-0.39	9.00	5.00	0.552	24.0	0.0	
08.02.2026	89.36	44.76	44.60	12.26	12.31	-0.41	11.78	12.25	-3.91	-0.47	9.00	5.00	0.527	24.0	0.0	
09.02.2026	96.79	46.06	50.73	11.99	11.98	0.08	11.51	11.87	-3.08	-0.36	9.00	5.00	0.587	24.0	0.0	
10.02.2026	102.71	47.73	54.98	12.02	11.96	0.50	11.54	11.72	-1.55	-0.18	9.00	5.00	0.638	24.0	0.0	
11.02.2026	102.84	47.65	55.19	12.01	11.94	0.58	11.53	11.74	-1.80	-0.21	9.00	5.00	0.639	24.0	0.0	
12.02.2026	92.82	44.95	47.87	11.83	11.85	-0.17	11.35	11.79	-3.80	-0.44	9.00	5.00	0.545	24.0	0.0	
13.02.2026	86.81	42.83	43.98	11.60	11.67	-0.60	11.21	11.67	-4.02	-0.46	9.00	5.00	0.492	24.0	0.0	
14.02.2026	79.40	41.40	38.00	11.85	11.97	-1.01	11.54	11.97	-3.66	-0.43	9.00	5.00	0.440	24.0	0.0	
15.02.2026	72.88	38.27	34.61	10.86	11.04	-1.64	10.62	11.04	-3.88	-0.42	9.00	5.00	0.366	24.0	0.0	
16.02.2026	76.86	40.35	36.51	11.87	12.02	-1.26	11.63	12.02	-3.30	-0.39	9.00	5.00	0.426	24.0	0.0	
17.02.2026	80.27	40.93	39.34	11.44	11.57	-1.13	11.17	11.57	-3.52	-0.40	9.00	5.00	0.442	24.0	0.0	
18.02.2026	88.66	42.49	46.17	11.36	11.43	-0.61	10.98	11.43	-4.02	-0.45	9.00	5.00	0.507	24.0	0.0	
19.02.2026	92.67	44.13	48.54	11.68	11.72	-0.34	11.20	11.70	-4.37	-0.50	9.00	5.00	0.543	24.0	0.0	
20.02.2026	91.52	43.59	47.93	11.58	11.61	-0.26	11.10	11.58	-4.23	-0.48	9.00	5.00	0.535	24.0	0.0	
21.02.2026	86.58	42.19	44.39	11.43	11.52	-0.78	11.02	11.52	-4.44	-0.50	9.00	5.00	0.489	24.0	0.0	
22.02.2026	92.26	43.44	48.82	11.33	11.36	-0.26	10.90	11.36	-4.13	-0.46	9.00	5.00	0.531	24.0	0.0	
23.02.2026	94.14	44.40	49.74	11.57	11.59	-0.17	11.09	11.59	-4.41	-0.50	9.00	5.00	0.552	24.0	0.0	
24.02.2026	86.39	42.54	43.85	11.36	11.43	-0.61	11.02	11.42	-3.57	-0.40	9.00	5.00	0.485	24.0	0.0	
25.02.2026	87.77	42.90	44.87	11.70	11.72	-0.17	11.32	11.70	-3.30	-0.38	9.00	5.00	0.508	24.0	0.0	
26.02.2026	92.63	44.64	47.99	11.80	11.78	0.17	11.32	11.74	-3.64	-0.42	9.00	5.00	0.545	24.0	0.0	
27.02.2026	90.43	43.58	46.85	11.61	11.56	0.43	11.13	11.56	-3.79	-0.43	9.00	5.00	0.522	24.0	0.0	
28.02.2026	90.55	43.56	46.99	11.65	11.61	0.34	11.17	11.61	-3.86	-0.44	9.00	5.00	0.526	24.0	0.0	
Средние:	89.93	43.83	46.10	---	---	-0.32	---	---	-3.52	---	9.00	5.00	---	---	---	
Итого:	---	---	---	330.35	331.39	---	318.43	329.76	---	-11.33	---	---	14.711	672.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.01.2026	10408.39	10419.16	10132.16	10312.99	-180.83	313.402	27107.0	1.0
28.02.2026	10738.74	10750.55	10450.59	10642.75	-192.16	328.113	27779.0	1.0
Итого:	330.35	331.39	318.43	329.76	-11.33	14.711	672.0	0.0

Представитель абонента

Представитель энергоснабжающей организации