

Отчет о суточных параметрах ГВС
(01.03.2026 0:00:00 - 31.03.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")
Прибор: Карат-30X Заводской номер: 11432221
Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.03.2026	52.70	2.394	2.363	3.42	0.113	24.0		Ok
02.03.2026	53.49	1.884	1.859	3.69	0.090	24.0		Ok
03.03.2026	53.23	1.602	1.581	3.61	0.076	24.0		Ok
04.03.2026	53.47	1.740	1.717	3.77	0.083	24.0		Ok
05.03.2026	53.45	2.035	2.008	3.67	0.097	24.0		Ok
06.03.2026	53.59	2.028	2.001	3.65	0.097	24.0		Ok
07.03.2026	53.26	1.714	1.691	3.66	0.082	24.0		Ok
08.03.2026	53.86	2.020	1.993	3.63	0.097	24.0		Ok
09.03.2026	52.77	2.072	2.045	3.53	0.098	24.0		Ok
10.03.2026	51.84	1.696	1.675	3.61	0.078	24.0		Ok
11.03.2026	53.79	1.839	1.814	3.69	0.088	24.0		Ok
12.03.2026	53.12	2.095	2.067	3.67	0.099	24.0		Ok
13.03.2026	53.52	2.301	2.270	3.74	0.110	24.0		Ok
14.03.2026	52.53	1.885	1.861	3.73	0.088	24.0		Ok
15.03.2026	51.62	1.957	1.933	3.62	0.090	24.0		Ok
16.03.2026	35.76	2.841	2.825	4.52	0.087	24.0		Ok
17.03.2026	52.29	2.032	2.006	3.85	0.095	24.0		Ok
18.03.2026	54.79	2.289	2.257	3.66	0.112	24.0		Ok
19.03.2026	52.69	1.898	1.873	3.69	0.089	24.0		Ok
20.03.2026	51.97	1.957	1.932	3.90	0.091	24.0		Ok
21.03.2026	51.56	1.902	1.878	3.87	0.087	24.3		Ok
22.03.2026	53.36	2.496	2.463	3.59	0.119	24.1		Ok
23.03.2026	53.35	2.325	2.294	3.74	0.111	24.0		Ok
24.03.2026	52.59	2.354	2.324	3.85	0.111	24.0		Ok
25.03.2026	53.26	2.246	2.216	3.95	0.107	24.0		Ok
26.03.2026	52.06	2.063	2.037	3.96	0.096	24.0		Ok
27.03.2026	53.16	2.337	2.306	3.82	0.111	24.0		Ok
28.03.2026	53.49	2.044	2.017	3.81	0.098	24.0		Ok
29.03.2026	53.09	2.035	2.008	3.38	0.096	24.0		Ok
30.03.2026	52.09	1.698	1.677	3.70	0.079	24.0		Ok
31.03.2026	52.42	1.784	1.761	3.81	0.083	24.0		Ok
Средние:	52.39	---	---	3.73	---	---		
Итого:	---	63.563	62.751	---	2.960	744.3		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
28.02.2026	2437.479	2404.684	116.694	37399.7
31.03.2026	2501.042	2467.435	119.654	38144.0
Итого:	63.563	62.751	2.960	744.3

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.03.2026 0:00:00 - 31.03.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

ПРЭМ SN 334995

Подача:

ПРЭМ SN 333703

Обратка:

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2026	87.11	42.69	44.42	11.60	11.52	0.69	11.15	11.52	-3.26	-0.37	9.00	5.00	0.494	24.0	0.0	
02.03.2026	84.39	42.31	42.08	11.61	11.51	0.87	11.31	11.51	-1.75	-0.20	9.00	5.00	0.477	24.0	0.0	
03.03.2026	88.87	43.87	45.00	11.88	11.82	0.51	11.43	11.78	-3.02	-0.35	9.00	5.00	0.515	24.0	0.0	
04.03.2026	91.21	43.38	47.83	11.43	11.38	0.44	11.02	11.38	-3.21	-0.36	9.00	5.00	0.528	24.0	0.0	
05.03.2026	94.62	44.79	49.83	11.60	11.57	0.26	11.12	11.55	-3.79	-0.43	9.00	5.00	0.557	24.0	0.0	
06.03.2026	93.74	44.68	49.06	11.69	11.67	0.17	11.21	11.62	-3.59	-0.41	9.00	5.00	0.551	24.0	0.0	
07.03.2026	91.67	44.46	47.21	11.83	11.79	0.34	11.35	11.78	-3.72	-0.43	9.00	5.00	0.538	24.0	0.0	
08.03.2026	92.58	43.76	48.82	11.39	11.34	0.44	10.91	11.31	-3.60	-0.40	9.00	5.00	0.534	24.0	0.0	
09.03.2026	99.79	44.89	54.90	11.54	11.56	-0.17	11.06	11.46	-3.55	-0.40	9.00	5.00	0.612	24.0	0.0	
10.03.2026	99.15	46.06	53.09	12.06	12.08	-0.17	11.58	11.96	-3.23	-0.38	9.00	5.00	0.615	24.0	0.0	
11.03.2026	83.88	42.50	41.38	12.17	12.06	0.91	11.81	12.06	-2.09	-0.25	9.00	5.00	0.490	24.0	0.0	
12.03.2026	70.71	37.74	32.97	11.08	10.89	1.73	10.84	10.89	-0.46	-0.05	9.00	5.00	0.359	24.0	0.0	
13.03.2026	67.78	37.42	30.36	11.47	11.26	1.85	11.23	11.26	-0.27	-0.03	9.00	5.00	0.339	24.0	0.0	
14.03.2026	66.73	37.87	28.86	11.68	11.48	1.73	11.44	11.48	-0.35	-0.04	9.00	5.00	0.332	24.0	0.0	
15.03.2026	67.19	38.52	28.67	11.87	11.68	1.61	11.63	11.68	-0.43	-0.05	9.00	5.00	0.336	24.0	0.0	
16.03.2026	67.57	39.24	28.33	12.24	12.02	1.81	12.00	12.02	-0.17	-0.02	9.00	5.00	0.341	24.0	0.0	
17.03.2026	67.20	39.06	28.14	11.95	11.75	1.69	11.71	11.75	-0.34	-0.04	9.00	5.00	0.330	24.0	0.0	
18.03.2026	66.69	39.55	27.14	12.34	12.13	1.72	12.10	12.10	0.00	0.00	9.00	5.00	0.327	24.0	0.0	
19.03.2026	66.92	40.04	26.88	12.15	11.93	1.83	11.93	11.93	0.00	0.00	9.00	5.00	0.320	24.0	0.0	
20.03.2026	65.07	36.14	28.93	9.53	9.33	2.12	9.29	9.33	-0.43	-0.04	9.00	5.00	0.267	24.0	0.0	
21.03.2026	65.43	36.05	29.38	9.66	9.45	2.20	9.42	9.45	-0.32	-0.03	9.00	5.00	0.276	24.0	0.0	
22.03.2026	65.48	36.05	29.43	9.70	9.50	2.08	9.46	9.50	-0.42	-0.04	9.00	5.00	0.277	24.0	0.0	
23.03.2026	66.06	37.11	28.95	10.58	10.38	1.91	10.34	10.38	-0.39	-0.04	9.00	5.00	0.297	24.0	0.0	
24.03.2026	65.43	37.38	28.05	10.88	10.69	1.76	10.64	10.69	-0.47	-0.05	9.00	5.00	0.299	24.0	0.0	
25.03.2026	65.46	37.55	27.91	10.69	10.49	1.89	10.45	10.49	-0.38	-0.04	9.00	5.00	0.292	24.0	0.0	
26.03.2026	65.54	37.62	27.92	10.89	10.69	1.85	10.65	10.69	-0.37	-0.04	9.00	5.00	0.297	24.0	0.0	
27.03.2026	65.75	37.95	27.80	11.29	11.10	1.70	11.05	11.10	-0.45	-0.05	9.00	5.00	0.308	24.0	0.0	
28.03.2026	65.45	38.31	27.14	10.86	10.67	1.76	10.62	10.67	-0.47	-0.05	9.00	5.00	0.288	24.0	0.0	
29.03.2026	64.89	37.38	27.51	10.34	10.15	1.85	10.10	10.15	-0.49	-0.05	9.00	5.00	0.277	24.0	0.0	
30.03.2026	65.94	39.06	26.88	11.53	11.35	1.57	11.29	11.35	-0.53	-0.06	9.00	5.00	0.305	24.0	0.0	
31.03.2026	65.55	38.72	26.83	11.49	11.29	1.76	11.25	11.29	-0.35	-0.04	9.00	5.00	0.305	24.0	0.0	
Средние:	75.29	40.07	35.22	---	---	1.31	---	---	-1.35	---	9.00	5.00	---	---	---	
Итого:	---	---	---	351.02	346.53	---	341.39	346.13	---	-4.74	---	---	12.083	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
28.02.2026	10738.74	10750.55	10450.59	10642.75	-192.16	328.113	27779.0	1.0
31.03.2026	11089.76	11097.08	10791.98	10988.88	-196.90	340.196	28523.0	1.0
Итого:	351.02	346.53	341.39	346.13	-4.74	12.083	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации