

Отчет о суточных параметрах ГВС
(01.05.2026 0:00:00 - 31.05.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: Карат-30X Заводской номер: 11432221

Точка измерения: Подсистема 1; Ресурс: ГВС

Схема измерений: Пользовательская схема узла учета потребителя

Дата	t1 °C	V1 м3	M1 т	P1 кгс/см2	Q1 Гкал	Траб ч	NS	gNSCode
01.05.2026	52.45	1.573	1.553	4.20	0.074	24.0		Ok
02.05.2026	51.06	1.569	1.550	4.25	0.071	24.0		Ok
03.05.2026	51.22	1.474	1.456	3.95	0.067	24.0		Ok
04.05.2026	51.93	1.686	1.665	3.88	0.078	24.0		Ok
05.05.2026	51.61	1.619	1.599	3.98	0.074	24.0		Ok
06.05.2026	51.20	1.449	1.431	4.00	0.066	24.0		Ok
07.05.2026	50.51	1.672	1.652	4.10	0.075	24.0		Ok
08.05.2026	50.69	1.856	1.834	4.18	0.084	24.0		Ok
09.05.2026	50.53	1.621	1.602	4.20	0.073	24.0		Ok
10.05.2026	50.64	1.968	1.944	4.18	0.089	24.0		Ok
11.05.2026	51.83	1.938	1.914	3.82	0.090	24.0		Ok
12.05.2026	51.36	1.923	1.899	4.02	0.088	24.0		Ok
13.05.2026	51.07	2.043	2.018	3.98	0.093	24.0		Ok
14.05.2026	52.34	1.931	1.906	4.01	0.090	24.0		Ok
15.05.2026	51.05	1.827	1.805	4.13	0.083	24.0		Ok
16.05.2026	51.97	1.748	1.726	3.97	0.081	24.0		Ok
17.05.2026	50.40	1.719	1.699	3.75	0.077	24.0		Ok
18.05.2026	50.55	2.040	2.016	3.79	0.092	24.0		Ok
19.05.2026	50.46	1.396	1.379	3.91	0.063	24.0		Ok
20.05.2026	51.52	1.541	1.522	3.98	0.071	24.0		Ok
21.05.2026	52.34	2.192	2.164	4.02	0.102	24.0		Ok
22.05.2026	52.29	1.747	1.725	4.15	0.082	24.0		Ok
23.05.2026	50.41	1.507	1.489	4.03	0.068	24.0		Ok
24.05.2026	50.06	1.430	1.413	3.92	0.064	24.0		Ok
25.05.2026	49.62	1.734	1.714	3.82	0.076	24.0		Ok
26.05.2026	50.44	1.693	1.673	4.07	0.076	24.0		Ok
27.05.2026	49.76	1.403	1.387	4.08	0.062	24.0		Ok
28.05.2026	48.25	1.213	1.200	4.11	0.052	24.0		Ok
29.05.2026	48.29	1.093	1.081	4.24	0.047	24.0		Ok
30.05.2026	50.36	1.315	1.299	4.28	0.059	24.0		Ok
31.05.2026	50.04	1.165	1.151	4.12	0.052	24.0		Ok
Средние:	50.85	---	---	4.03	---	---		
Итого:	---	51.085	50.465	---	2.318	744.0		

Дата	V1 м3	M1 т	Q1 Гкал	Траб ч
30.04.2026	2557.984	2523.643	122.326	38864.0
31.05.2026	2609.069	2574.107	124.643	39608.0
Итого:	51.085	50.464	2.318	744.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.05.2026 0:00:00 - 31.05.2026 0:00:00)

Объект: Пермский край, Пермь г, Закамская ул, д. 5 (4 ООО "ЗУК")

Прибор: ВКТ-7 Заводской номер: 00115028

Точка измерения: ТВ1; Ресурс: ТС

Счетчик воды:

ПРЭМ SN 334995

Подача:

ПРЭМ SN 333703

Обратка:

Датчик температуры:

КТСП-Н SN 32048г

КТСП-Н SN 32048х

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.05.2026	64.94	36.50	28.44	9.63	9.46	1.78	9.39	9.46	-0.74	-0.07	9.00	5.00	0.267	24.0	0.0	
02.05.2026	65.42	37.31	28.11	10.14	9.96	1.79	9.90	9.96	-0.60	-0.06	9.00	5.00	0.280	24.0	0.0	
03.05.2026	65.79	38.63	27.16	10.86	10.66	1.86	10.62	10.66	-0.38	-0.04	9.00	5.00	0.289	24.0	0.0	
04.05.2026	64.92	38.59	26.33	6.59	6.46	1.99	6.45	6.46	-0.15	-0.01	9.00	5.00	0.171	24.0	0.0	*
05.05.2026	29.66	27.76	1.90	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
06.05.2026	28.85	27.32	1.53	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
07.05.2026	28.64	27.17	1.47	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
08.05.2026	27.24	25.95	1.29	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
09.05.2026	26.74	24.69	2.05	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
10.05.2026	24.85	23.18	1.67	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
11.05.2026	24.47	23.05	1.42	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
12.05.2026	25.32	23.77	1.55	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
13.05.2026	26.07	24.30	1.77	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
14.05.2026	26.60	24.97	1.63	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
15.05.2026	26.93	25.44	1.49	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
16.05.2026	27.31	25.86	1.45	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
17.05.2026	27.93	26.39	1.54	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
18.05.2026	28.21	26.67	1.54	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
19.05.2026	27.94	26.48	1.46	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
20.05.2026	27.95	26.63	1.32	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
21.05.2026	27.71	26.29	1.42	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
22.05.2026	27.27	25.98	1.29	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
23.05.2026	28.13	26.74	1.39	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
24.05.2026	28.26	26.84	1.42	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
25.05.2026	28.07	26.67	1.40	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
26.05.2026	28.32	26.91	1.41	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
27.05.2026	28.51	27.11	1.40	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
28.05.2026	27.83	26.62	1.21	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
29.05.2026	26.70	25.62	1.08	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
30.05.2026	26.68	25.42	1.26	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
31.05.2026	26.54	25.30	1.24	0.00	0.00	---	0.00	0.00	---	0.00	9.00	5.00	0.000	24.0	0.0	*
Средние:	32.25	27.42	4.83	---	---	0.24	---	---	-0.06	---	9.00	5.00	---	---	---	
Итого:	---	---	---	37.22	36.54	---	36.36	36.54	---	-0.18	---	---	1.007	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	Т	Т	Т	Гкал	ч	ч
30.04.2026	27.42	27.30	26.73	27.30	-0.57	0.872	63.0	0.0
31.05.2026	52.79	51.87	51.55	51.87	-0.32	1.439	783.0	0.0
Итого:	25.37	24.57	24.82	24.57	0.25	0.567	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации